Harnett County Department of Public Health

Improvement Permit A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 12558 McDougald Rd (SR 1229) ISSUED TO: Carl Zabel SUBDIVISION REPAIR X EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: Existing Proposed Wastewater System Type: Existing Projected Daily Flow: 240 Number of bedrooms: Number of Occupants: X No Basement Yes May be required based on final location and elevations of facilities X No Pump Required: Yes X Five years Type of Water Supply: Community Public Well Distance from well ______feet Permit valid for: ■ No expiration Permit conditions: Date: 04-27-23 SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. PROPERTY LOCATION: 12558 McDougald Rd (SR 1229) ISSUED TO: Carl Zabel SUBDIVISION × Repair Facility Type: Existing Expansion Basement? Yes Basement Fixtures? Yes Type of Wastewater System** (Initial) Wastewater Flow: 240 GPD (See note below, if applicable) Tank and dbox (Repair) Number of trenches Existing Installation Requirements/Conditions Septic Tank Size 1000 gallons Exact length of each trench Existing Trench Spacing: Existing Feet on Center Soil Cover: Existing inches Trenches shall be installed on contour at a Pump Tank Size _____ Maximum Trench Depth of: Existing (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: _____ ft. TDH vs. _ inches below pipe inches above pipe Aggregate Depth: Conditions: Set New Septic Tank & Dbox. Run Drain Cine & Clear root blockage. Tie New Dook pito lines WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.

NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: Date: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This

SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Date: 04-27-23 Authorized State Agent: _


Construction Authorization Expiration Date: 10-27-23

Application # EH2304-0008

Repair

Harnett County Department of Public Health Site Sketch

Property Location: 12558 McDougald Rd (SR 1229)			11000
Issued To: Carl Zabel	Subdivision	Lot #	
Authorized State Agent:	Mah an RETS	Date: 04-27-23	



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.