

North Carolina State Laboratory of Public Health

Environmental Sciences

Inorganic Chemistry

Certificate of Analysis

4312 District Drive MSC 1918

Raleigh, NC 27699-1918

http://slph.ncpublichealth.com Phone: 919-733-7308 Fax: 919-715-8611

FINAL REPORT

Report to: JAMES MANHART

HARNETT CO ENVIRONMENTAL HEALTH

307 CORNELIUS HARNETT BLVD

LILLINGTON, NC 27546

Name of System:

Allison Haggerty

5 Nettie Weaver Rd

Angier, NC 27501

EIN: 566000306EH

Delivery: NC Courier

StarLiMS ID: ES230518-0042

Date Collected:

05/16/2023

Time Collected:

11:30

By: James Manhart

Well water

Date Received:

05/18/2023

Time Received:

08:25

Well Permit No.

Sample Type: Sample Source: Raw

Sampling Point: Receipt Temp. :

nt: Well head

GPS Number:

Profile: Inorganic Chemical + Metals I

Analyte	Test Result	Allowable Limit	Unit	Qualifier(s
Arsenic	0.002	0.010	mg/L	
Barium	0.165	2.0	mg/L	
Cadmium	< 0.0005	0.005	mg/L	
Calcium	10		mg/L	
Chloride	<5	250	mg/L	
Chromium	<0.02	0.10	mg/L	
Copper	<0.01	1.3	mg/L	
Fluoride	0.274	4.00	mg/L	
Iron	4.67	0.30	mg/L	
Lead	< 0.003	0.015	mg/L	
Magnesium	4		mg/L	
Manganese	0.541	0.05	mg/L	
Mercury	<0.0004	0.002	mg/L	
Nickel	<0.01	0.1	mg/L	
pH	7.4		N/A	
Selenium	<0.005	0.05	mg/L	
Silver	<0.01	0.10	mg/L	
Sodium	7.6		mg/L	
Sulfate	10.1	250	mg/L	
Total Alkalinity	48		mg/L	
Total Hardness	38		mg/L	
Zinc	0.18	5.0	mg/L	

Report Date:

06/02/2023

Reported By:

Marc Komlos



Private Well Information and Use Recommendations

For Inorganic Chemical Contaminants

For morganic chemical contaminants
Sample ID #: Sample Name: AllISON Haggerty Reviewer: Marc Komlos (James & Manilanter 125148)
Sample 1D#. Reviewer. Mine Nomes to Wanter
TEST RESULTS AND USE RECOMMENDATIONS
1. Your well water meets federal drinking water standards <i>for inorganic chemicals</i> . Your water can be used for drinking, cooking, washing, cleaning, bathing, and showering based on the <i>inorganic chemical results only</i> . You may have other water sampling results that are not taken into account in this report.
2. The following substance(s) exceeded federal drinking water standards or the North Carolina 2L calculated health levels. The North Carolina Division of Public Health recommends that your well water not be used for drinking and cooking unless you install a water treatment system to remove the checked substance(s). However, it may be used for washing, cleaning, bathing, and showering based on the <i>inorganic chemical results only</i> .
□ Arsenic □ Barium □ Cadmium □ Chromium □ Copper □ Fluoride □ Iron □ Lead □ Manganese □ Mercury □ Nickel □ Nitrate/Nitrite □ Selenium □ Silver □ Zinc □ Nickel □ Nitrate/Nitrite □ Selenium □ Silver
3. While your lead levels do not exceed federal or state standards, the North Carolina Division of Public Health has concerns with any detection of lead. Should you have any questions please contact the NC Private Well and Health Program at (919) 707 - 5900.
4. Re-sample for lead and /or copper. Take a first draw and 30-second flush sample inside the house (preferably the
kitchen sink) and a first draw and 4 minutes flush sample at the wellhead to determine the source of the lead and/or copper.
5. The following substance(s) exceeded aesthetic drinking water standards. Your water can be used for drinking, cooking, washing, cleaning, bathing, and showering based on the <i>inorganic chemical results only</i> , but aesthetic problems such as bad taste, odor, staining of porcelain, etc. may occur. You may want to install a household water treatment system to address aesthetic problems.
□Chloride □Copper □Flouride □Iron □Manganese □pH □Silver □Sulfate □Zinc
6. a. Sodium levels exceed the U.S. Environmental Protection Agency's (USEPA) Health Advisory level for sodium of 20 mg/l. The North Carolina Division of Public Health recommends that only individuals on no or low sodium-restricted diets not use this water for drinking or cooking. It may be used for washing, cleaning, bathing, and showering based on the <i>inorganic chemical results only</i> .
☐b. Your sodium level exceeds 30 mg/L and may pose aesthetic issues such as bad taste, odor, staining of porcelain, e
7. Re-sampling is recommended inmonths, to reinvestigate