

Harnett County Department of Public Health

Repair

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Har-low Realty
 NEW REPAIR EXPANSION
 Type of Structure: Existing SWMH
 Proposed Wastewater System Type: 25% reduction
 Projected Daily Flow: 600 GPD
 Number of bedrooms: 5 Number of Occupants: 10 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet
 Permit conditions: _____

PROPERTY LOCATION: 151 GrogTown Ln
 SUBDIVISION: Brentwood II MHP LOT # _____
 Site Improvements required prior to Construction Authorization Issuance: _____

Permit valid for: Five years
 No expiration

Authorized State Agent: Moh R. REHS Date: 5-30-23 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Har-low Realty
 Facility Type: Existing SWMH New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** _____ (Initial) Wastewater Flow: 600 GPD
 (See note below, if applicable)

PROPERTY LOCATION: 151 GrogTown Ln
 SUBDIVISION: Brentwood II MHP LOT # _____

Installation Requirements/Conditions
 Septic Tank Size Existing gallons
 Pump Tank Size _____ gallons

Number of trenches 1
 Exact length of each trench 375 feet
 Trenches shall be installed on contour at a
 Maximum Trench Depth of: 12 inches
 (Trench bottoms shall be level to $\pm 1/4$ "
 in all directions)

Trench Spacing: 9 Feet on Center
 Soil Cover: 6 inches
 (Maximum soil cover shall not exceed
 36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: _____ inches below pipe
 _____ inches above pipe
 _____ inches total

Conditions: Will need 6" of Group II or Group III Soil for
 Cover over ENTIRE Drain Field area

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH


Authorized State Agent: Moh R. REHS Date: 5-30-23
 Construction Authorization Expiration Date: 5-30-28

Application # EH2305-0019

Harnett County Department of Public Health Site Sketch

Property Location: 181 Graytown Ln
Issued To: Harlow Realty Subdivision BRAWOOD II MHP Lot # _____
Authorized State Agent: Mah [Signature] REHS Date: 5-30-23

* Must bring in 6" of Group II or Group III Soil for cover over entire Drain Field Area



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.