

Harnett County Department of Public Health Improvement Permit

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: 43 Breezeway Ln (SR 3400)
 SUBDIVISION: Carolina Seasons Phase 2 LOT # 17

ISSUED TO: Henry Manning
 NEW REPAIR EXPANSION
 Type of Structure: existing house
 Proposed Wastewater System Type: pump to 25% reduction
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet
 Permit conditions: _____ Permit valid for: Five years No expiration

Permit Good For 6 months

Authorized State Agent: Moh W. REHS Date: 08-04-23 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules 1950, 1952, 1954, 1955, 1956, 1957, 1958 and 1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout

ISSUED TO: Henry Manning PROPERTY LOCATION: 43 Breezeway Ln (SR 3400)
 SUBDIVISION: Carolina Seasons Phase 2 LOT # 17

Facility Type: existing house New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** pump to 25% reduction (Initial Wastewater Flow: 360 GPD)
 (See note below, if applicable
pump to 25% reduction (Repair)

Installation Requirements/Conditions
 Septic Tank Size existing gallons
 Pump Tank Size 1000 gallons
 Number of trenches 1
 Exact length of each trench 180 feet
 Trench Spacing: 9 Feet on Center
 Trenches shall be installed on contour at a
 Maximum Trench Depth of: 24 inches (Maximum soil cover shall not exceed
 (Trench bottoms shall be level to $\pm 1/4"$ 36" above the trench bottom)
 in all directions)

Pump Requirements: _____ ft. TDH vs _____ GPM Aggregate Depth: _____ inches below pipe
 _____ inches above pipe
 _____ inches total

Conditions: 36" Deep Curtain Drain will be required 10' + Above The New Drain Field

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____
 This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: Moh W. REHS Date: 08-04-23
 Construction Authorization Expiration Date: 8-4-28

Application # EH2307-0005

Harnett County Department of Public Health Site Sketch

Property Location: 43 Breezeway Ln (SR 3400)


Issued To: Henry Manning

Subdivision Carolina Seasons Phase 2

Lot # 17

Authorized State Agent: *Mal R. REHS*

Date: 08-04-23



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.