

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: D. Hoerle Applicant:
 Address: 189 Seawell Rosser Date Evaluated: 10-26-23
 Proposed Facility: 4BR Home Design Flow (.1949): 480 GPD Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L ₁ SS 4%	0-23	vG ⁺ /SL	Vf ₁ , MS, mp, Sp	—	—	—	—	P.S.
		23-48	sBk/SC	Vf ₁ , SS, Sp, Sp ₂	10YR 7/1 @ 33"	48"	—	—	0.3
2	L ₁ SS 4%	0-23 23-48	vG ⁺ /SL S ₁ S	Vf ₁ , MS, mp, Sp	10YR 7/1 @ 34"	—	—	—	P.S.
		23-48	sBk/SC	Vf ₁ , SS, Sp, Sp ₂	—	48"	—	—	0.3
3		0-33	vG ⁺ /SL	Vf ₁ , MS, mp, Sp	—	—	—	—	P.S.
		33-48	sBk/SC	Vf ₁ , SS, Sp, Sp ₂	10YR 7/1 @ 37"	48"	—	—	0.3

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <u>P.S.</u> Evaluated By: <u>MLH/REHS</u> Others Present: <u>AT</u>
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Site LTAR	0.3	0.3	

COMMENTS: _____

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTLY STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM	S-STICKY VS-VERY STICKY
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT	0.6 - 0.3	EFI-EXTREMELY FIRM	NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE
 SG-SINGLE GRAIN
 M- MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, references or benchmark, and North)

