EH 2310-0007

Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section Sheet: Property ID: Lot #: File #: Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner:	Applicant: SACA	whittingt	on young		
Address: 10297 v	15 401 N	Date Evaluated:	19-16-23		
Proposed Facility: 5		Design Flow (.19	49): 240	Property Size:	
Location of Site:	/	Property Recorde	d:		
Water Supply:	Public	☐ Individual	Well	☐ Spring	Other
Evaluation Method:[Auger Boring	☐ Pit	Cut		
Type of Wastewater:	Sewa	ge 🔲 Ind	ustrial Process	☐ Mixed	

P R O F I L E	.1940	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS					
	Landscape Position/ Slope %		.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR	
	4-3%	0-24	SL	Mineralogy JEC/ gC/ NS/ NP FI/SBK/S/						
	4-3%	24 - 48	SCL	FI,SBK;S,P	43"-44"	48*+			.3	

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): P^S
Available Space (.1945)	System	/	Evaluated By: Jn/LL
System Type(s)		25%	Others Present:
Site LTAR		•3	

COMMENTS: ____

LANDSCAPE POSITIONS	GROUP	<u>TEXTURES</u>	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE	I	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY
FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE	П	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC
CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	Ш	SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3		SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC

IV SIC-SILTY CLAY 0.4 - 0.1 C-CLAY SC-SANDY CLAY

STRUCTURE SG-SINGLE GRAIN M- MASSIVE CR-CRUMB **GR-GRANULAR** SBK-SUBANGULAR BLOCKY MINERALOGY SLIGHTLY EXPANSIVE

EXPANSIVE

