[ / Evaluation	
[ ] Re-evaluation _	
	(number)

On-Site Wastewater Section (Review 12/2010)

North Carolina Department of Environment and Natural Resources

Division of Environmental Health

#### PREOCCUPANCY EVALUATION REPORT OF DRINKING WATER SUPPLY AND WASTEWATER FACILITIES FOR MIGRANT HOUSING

On 12-6-23, as required in G.S. 95-225(c) and (d), an evaluation was conducted of the drinking water supply and
wastewater system serving a migrant housing site composed of # of Mobile home units, # of House (s) and
Other type of housing/describe: located at l
(address or directions; use reverse if needed)  Angier N.C. 2750) and operated by DMG FATOMS THE (name of person[s]/company)
of 997 Matthews Millord Ros Angrew N.C. 27501
$\mathcal{O}_{ ext{(mailing address)}}$
*** PLEASE SUBMIT ONE REPORT FOR EACH SEPTIC SYSTEM ***
This report describes well/spring and sewage system (Number). (Use reverse for a drawing, if needed.)
The findings of this evaluation are as follows:
WATER SUPPLY
Community or non-transient-non-community water system under routine surveillance of Public Water Supply Section,  (yes/no) Division of Environmental Health  Private Water or Non-Community System  (yes/no)
At the time of inspection, there
15A NCAC 18A .1700 (attach copy of bacteriological sample). List deficiencies which were identified:
(Use reverse if necessary)
WASTEWATER FACILITIES
System to approval under 15A NCAC 18A .1900, "Laws and Rules for Sewage Treatment and Disposal (subject/not subject)  Systems." Explain, if not subject to approval
On-Site Septic Tank System [ ] Chemical Portable Toilets [ ] Others [ ] Privy(ies)
At the time of inspection, there
.1962) "Laws and Rules for Sewage Treatment and Disposal System." List deficiencies which were identified:
(Use reverse if necessary)  235-24 people  355-16 people  The wastewater system, to the best of my knowledge and belief, is sized to serve
The wastewater system, to the best of my knowledge and belief, is sized to serve
S M I SPRIS (maximum number)
Harnett County Environmental Health  Environmental Health Specialist  Health Department
Environmental Health Specialist Health Department
12-12-23 307 W. Cornelius Harnett Blvd.
Date Address
Forward copies to: Migrant Housing Operator  Department of Labor  Lillington, NC 27546
Agriculture Safety & Health Bureau 910-893-7547
Office Phone Number  DENR 3765 (Revised 2/2011)

North Carolina Division of Public Health Occupational and Environmental Epidemiology Branch, Epidemiology Section BIOLOGICAL ANALYSIS REPORT

Private well water information and recommendations

County: HATLISETT Name: DMG FATZMS FOC Sample ID Number: ES 231207-0044  Location: 997 Matthews Mill Pond Reviewer TM/KP1 Emmos
Location: 997 Matthews Mill Pond RAND Reviewer TM/KPI Commons
Initial Sample Confirmation Sample
BIOLOGICAL ANALYSIS RESULTS AND RECOMMENDATIONS FOR USES OF YOUR PRIVATE WELL WATER (These recommendations are based on biological analysis only.)
No coliform bacteria were found in your well water. Your water can be used for all purposes including drinking, cooking, washing dishes, bathing and showering.
Total coliform bacteria were detected in your water sample. Total Coliform are a group of related bacteria that are (with few exceptions) not harmful to humans. A variety of bacteria, parasites, and viruses, known as pathogens, can potentially cause health problems if humans ingest them. EPA considers total coliforms a useful indicator of other pathogens for drinking water. Total coliforms are used to determine the adequacy of water treatment and the integrity of the distribution system.
Your well water needs to be re-tested to verify that the result is accurate.
Fecal coliform bacteria were detected in the sample. Do not use the water for drinking, cooking, washing dishes, bathing or showering.
If the re-test shows contamination by bacteria contact your local health department for assistance. There

If the re-test shows contamination by bacteria contact your local health department for assistance. There may be a problem with the construction of the well, the groundwater source, or operation of the well. The well needs to be inspected by the local health department or a local well contractor to determine the problem with the well and to give guidance on how to correct the problem.

Your well water was tested for biological contaminants (total coliform and fecal coliform bacteria). The results were evaluated using the federal drinking water standards.

Drinking water may contain substances that can occur naturally in water or can be introduced into water from man-made sources. Total coliform bacteria are found in soil and fecal coliform bacteria are found in animal and human waste. Total coliform or fecal coliform bacteria in well water indicate that the well may have structural problems or that the well was not properly disinfected.

If you have been drinking the well water and are pregnant, nursing, have a child in the household under 5 years of age, or immunocompromised (such as an individual with AIDS, cancer, hepatitis, dialysis or surgical procedures) inform your physician of these results at your next visit.

If the contamination continues, you should investigate the possibility of drilling a new well or installing a point-of-entry disinfection unit, which can use chlorine, ultraviolet light, or ozone.

For further information, please contact your county health department or the Occupational and Environmental Epidemiology Branch at 919-707-5900.



## North Carolina State Laboratory of Public Health

### Environmental Sciences

# Microbiology **Certificate of Analysis**

4312 District Drive MSC 1918 Raleigh, NC 27699-1918

http://slph.ncpublichealth.com Phone: 919-733-7308 Fax: 919-715-8611

**FINAL REPORT** 

Report to: JAMES MANHART

HARNETT CO ENVIRONMENTAL HEALTH

307 CORNELIUS HARNETT BLVD

Lillington, NC 27546

Name of System:

**DMG Farms Inc** 

997 Matthews Mill Pond Rd

Angier, NC 27501

EIN: 566000306EH

Delivery:

**NC Courier** 

**Harnett County** 

StarLiMS ID: ES231207-0044

Date Collected:

12/06/2023

Time Collected:

11:00

James Manhart By:

Date Received:

12/07/2023

Time Received:

08:04

Sample Source: Well water

Sampling Point:

outside spigot

By: Julie Schiavone

Sample Type:

GPS No.

Treatment:

Well Permit No.

Comment:

**Colilert Profile** 

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			12/07/2023
E. coli	Absent			12/07/2023

Report Date:

12/08/2023

Reported By:

**KPLEMMONS** 

#### **Explanations of Coliform Analysis:**

If coliform bacteria are Absent, the water is considered safe for drinking purpose. If coliform bacteria are Present, the water is considered unsafe for drinking purpose. Presence of E. coli (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.