## Harnett County Department of Public Health

## Improvement Permit A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: SUBDIVISION ISSUED TO: REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance: NEW | Type of Structure: Proposed Wastewater System Type: Projected Daily Flow: Number of Occupants: \_\_\_\_\_max Number of bedrooms: Basement Yes May be required based on final location and elevations of facilities ☐ No Pump Required: Yes Five years Type of Water Supply: Community Public Well Distance from well \_\_\_\_\_\_feet Permit valid for: ■ No expiration Permit conditions: Authorized State Agent:: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules . 1950, . 1952, . 1954, . 1955, . 1956, . 1957, . 1958, and . 1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Michelle McDougald PROPERTY LOCATION: 155 Smoketree Dr LOT # SUBDIVISION Facility Type: Ext SFD Expansion Basement Fixtures? Yes ☐ No Basement? Yes No Type of Wastewater System\*\* (Initial) Wastewater Flow: 360 GPD (See note below, if applicable ) \_(Repair) Installation Requirements/Conditions Number of trenches Septic Tank Size 1000 gallons Exact length of each trench \_\_\_\_\_ Pump Tank Size \_\_\_\_\_ Trenches shall be installed on contour at a Soil Cover: \_\_inches \_gallons (Maximum soil cover shall not exceed Maximum Trench Depth of: (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: \_\_\_\_\_ft. TDH vs. \_ inches below pipe Conditions: Replace existing septic tank. WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to responsation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Date: 11/29/23 Authorized State Agent: Construction Authorization Expiration Date: 2/29/24 (OLIVER TOLKSDOF