

Harnett County Environmental Health

File/Permit Number: EH 2401-0010

IMPROVEMENT PERMIT

County: HARNETT

PIN/Lot Identifier: _____

Owner: Southern Wake Property Group Applicant: Southern Wake Property Group

Property Location: 66 Poole RD Erwin N.C. 28339

Subdivision (if applicable) _____ Lot #: _____ Block: _____ Section: _____

New Expansion System Relocation Change of Use

Facility Type: Exp SFD

Number of bedrooms: 3 Number of Occupants: 6 Other: _____

Design Wastewater Strength: Domestic High Strength Industrial Process Wastewater

Proposed Design Daily Flow: 360 GPD Proposed LTAR (Initial): - Proposed LTAR (Repair): -

Proposed Wastewater System Type*: _____ (Initial) Pump Required: Yes No May be required

Proposed Wastewater System Type*: Replace Ex Septic Tank (Repair) Pump Required: Yes No May be required

*Please include system classification for proposed wastewater system types in accordance with Rule .1301 Table XXXII

Effluent Standard: DSE HSE NSF/ANSI 40 TS-I TS-II RCW

Saprolite System (Initial): Yes No Saprolite System (Repair): Yes No

Fill System (Initial): Yes No If yes, specify: New Existing (when adding more than 6 inches of fill to system area provide a fill plan)

Fill System (Repair): Yes No If yes, specify: New Existing (when adding more than 6 inches of fill to system area provide a fill plan)

Usable Depth to LC (Initial)*: - Usable Depth to LC (Repair)*: - * Limiting Condition

Max. Trench Depth (Initial)†: - Max. Trench Depth (Repair)†: - † Measured on the downhill side of the trench

Artificial Drainage Required: Yes No If yes, please specify details: _____

Type of Water Supply: Private well Public well Shared well Municipal Supply Spring Other: _____

Drainfield location meets requirements of Rule .0508: Yes No Drainfield location meets requirements of Rule .0601: Yes No

Permit valid for: Five years [site plan submitted pursuant to GS 130A-334(13a)] No expiration [plat submitted pursuant to GS 130A-334(7a)]

Permit conditions:
Replace TANK + DBOX - IF NEEDS

Authorized Agent's Printed Name: JAMES E MARSHANT JR RBHS Expiration Date: 1-17-29

Authorized Agent's Signature: James E Marshant JR RBHS Date: 1-17-24

See attached site sketch

The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This permit is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.

Harnett County Environmental Health

File/Permit Number: EH 2401-0010

CONSTRUCTION AUTHORIZATION

County: HARNETT PIN/Lot Identifier: _____

Owner: _____ Applicant: Southern Wake Property Group

Property Location: 66 Poole Rd Erwin N.C. 28339

Facility Type: Ex SFD

Number of bedrooms: 3 Number of Occupants: 6 Other: _____

New Expansion Repair System Relocation Change of Use
Basement? Yes No Basement Fixtures? Yes No
Crawl Space? Yes No Slab Foundation? Yes No

Type of Wastewater System* TANK + D BOX Replace (Initial) TANK + D BOX Replacement (Repair)

*Please include system classification for proposed wastewater system types in accordance with Rule .1301 Table XXXII

Design Daily Flow: 360 GPD Wastewater Strength: Domestic High Strength Industrial Process Wastewater

Rule .0403(e) Engineering Design Utilizing Low-flow Fixtures and Low-flow Technologies (S.L. 2013-413 and 2014-120)? Yes No
(if yes, please provide engineering documentation)

Effluent Standard: DSE HSE NSF/ANSI 40 TS-I TS-II RCW

Type of Water Supply: Private well Public well Shared well Municipal Supply Spring Other: _____

Installation Requirements/Conditions

Septic Tank Size: 1000 gallons Total Trench/Bed Length: _____ feet Trench/Bed Spacing: _____ feet on center

Trench/Bed Width: _____ inches LTAR: _____ gpd/ft² Usable Depth to LC (Initial)*: _____ ^{Limiting condition}

Soil Cover: 6 inches Slope Corrected Maximum Trench/Bed Depth[†]: _____ inches ^{Measured on the downhill side of the trench}

Pump Tank Size (if applicable): FDG gallons Requires more than one pump? Yes No

Pump Requirements: _____ ft. TDH vs. _____ GPM Grease Trap Size (if applicable): _____ gallons

Distribution Method: Serial D-Box or Parallel Pressure Manifold(s) LPP Other: _____

Artificial Drainage Required: Yes No If yes, please specify details: _____

Legal Agreements (If the answer is "Yes" to any type of legal agreements, please attach a copy of the agreement.)

Multi-party Agreement Required [Rule .0204(g)]: Yes No

Easement, Right-of-Way, or Encroachment Agreement Required [Rule .0204(d)]: Yes No

Declaration of Restrictive Covenants: Yes No Pre-Construction Conference Required: Yes No

Management Entity Required: Yes No Minimum O&M Requirements: _____

Conditions: _____

Septic Tank + D Box if required.

The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached site sketch. This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be affected by a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of 15A NCAC 18E, or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit.

Authorized Agent's Printed Name: JAMES E MANDON JR REGAS Expiration Date: 1-17-29

Authorized Agent's Signature: James E Mandon Jr REGAS Date: 1-17-24

See attached site sketch

Harnett County Environmental Health

SITE SKETCH

PIN 0589-60-4460.000

Permit Number EH 2401-0010

Southern Wake Property Group
Applicant's Name
James E. Manahan JR. REAS
Authorized State Agent

66 POOLE RD BRW
Subdivision/Section/Lot Number
1-17-24
Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

Scale = _____

