



Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

ph: 910-893-7550

fax: 910-893-9429

April 16th, 2024

Charles Levorse  
909 Prospect Church Rd  
Dunn, NC 28334

**Re: Status of Repair Application**

**To whom it may concern,**

An attempt was made to evaluate your property for issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are Set by surveyor need to be visible. (\$25.00 Fee incurred)
- 2. House Box needs to be marked to match site plan (\$25.00 Fee Incurred)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs undergrowth cleared, do not disturb the soil
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. **Other – Tank need replacing, possible D-Box replacing. Have contractor to dig up line connection to see if they are still usable. Contact Environmental Health once the leech lines were checked for any damage or blocking.**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,

Reynold Levocz R.E.H.S.  
Environmental Health Specialist  
Harnett County Department of Public Health

RL/kh

Copy: Central Permitting