

# Harnett County Environmental Health

File/Permit Number: EH2406-0002

## CONSTRUCTION AUTHORIZATION

County: Harnett PIN/Lot Identifier: 0528-48-2658

Owner: Tony McNeill Applicant: Tony McNeill

Property Location: 1050 Tim Currin Rd (SR 1250)

Facility Type: DWMH

Number of bedrooms: 3 Number of Occupants: 6 Other: \_\_\_\_\_

New       Expansion       Repair       System Relocation       Change of Use  
Basement?       Yes       No      Basement Fixtures?       Yes       No  
Crawl Space?       Yes       No      Slab Foundation?       Yes       No  
Type of Wastewater System\* \_\_\_\_\_ (Initial)      25% reduction \_\_\_\_\_ (Repair)

*\*Please include system classification for proposed wastewater system types in accordance with Rule .1301 Table XXXII*

Design Daily Flow: 360 GPD      Wastewater Strength:  Domestic       High Strength       Industrial Process Wastewater

Rule .0403(e) Engineering Design Utilizing Low-flow Fixtures and Low-flow Technologies (S.L. 2013-413 and 2014-120)?       Yes       No  
*(if yes, please provide engineering documentation)*

Effluent Standard:       DSE       HSE       NSF/ANSI 40       TS-I       TS-II       RCW

Type of Water Supply:       Private well       Public well       Shared well       Municipal Supply       Spring       Other: \_\_\_\_\_

### Installation Requirements/Conditions

Septic Tank Size: existing gallons      Total Trench/Bed Length: 225 feet      Trench/Bed Spacing: 9 feet on center

Trench/Bed Width: 36 inches      LTAR: .4 gpd/ft<sup>2</sup>      Usable Depth to LC (Initial)\*: 36 <sup>\*Limiting condition</sup>

Soil Cover: 6 inches      Slope Corrected Maximum Trench/Bed Depth†: 24 inches <sup>† Measured on the downhill side of the trench</sup>

Pump Tank Size (if applicable): \_\_\_\_\_ gallons      Requires more than one pump?       Yes       No

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM      Grease Trap Size (if applicable): \_\_\_\_\_ gallons

Distribution Method:       Serial       D-Box or Parallel       Pressure Manifold(s)       LPP       Other: \_\_\_\_\_

Artificial Drainage Required: Yes  No  If yes, please specify details: \_\_\_\_\_

### Legal Agreements *(If the answer is "Yes" to any type of legal agreements, please attach a copy of the agreement.)*

Multi-party Agreement Required [Rule .0204(g)]:       Yes       No

Easement, Right-of-Way, or Encroachment Agreement Required [Rule .0204(d)]:       Yes       No


Declaration of Restrictive Covenants:       Yes       No      Pre-Construction Conference Required: Yes  No

Management Entity Required:       Yes       No      Minimum O&M Requirements: \_\_\_\_\_

Conditions: \_\_\_\_\_

**The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached site sketch. This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be affected by a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of 15A NCAC 18E, or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit.**

Authorized Agent's Printed Name: Mark Osborne REHS      Expiration Date: 6-13-29

Authorized Agent's Signature:       Date: 6-13-24

**\*See attached site sketch\***

# Harnett County Environmental Health

## SITE SKETCH

PIN 0528-48-2658


Permit Number EH2406-0002

Tony McNeill  
Applicant's Name  
Mark Osborne REHS *Mark Osborne REHS*  
Authorized State Agent

Subdivision/Section/Lot Number  
6-13-24  
Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

Scale = NTS



← Tim Curria Rd →