

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

July 8th, 2024

Josh & Maranda Walsh
130 Red Robin Drive
Dunn, NC 28334

Re: Status of Permit Application-EH2406-0012

To whom it may concern,

An attempt was made to evaluate your property for issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines every 50'. All property survey corners need to be uncovered and demonstrated. (\$25.00 Fee incurred)
- 2. House Box needs to be corrected and remarked/demonstrated. (25.00 Fee Incurred)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs undergrowth cleared, do not disturb the soil
- 5. Driveway not shown on site plan
- 6. Backhoe Pits Required-
- 7. **Other – Head of Department, Supervisor and Myself all evaluated the site and came to the conclusion that the system relocation is denied due to limited space and usable soil. The current repair system would be a pre-treatment system if and when needed. Spoke with homeowner on 7/8 and explained that the current system could be brought up to code if: The pool was moved 5' off septic lines and removed. Tank was 1' off of porch/pillar. Have septic contractor clean out and evaluate septic drain lines that were under the pool to determine if they are crushed or damaged.**

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7525 ext. 2 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

RL/kh
Copy: Central Permitting