

### North Carolina State Laboratory of Public Health

### Environmental Sciences

# Organic Chemistry

4312 District Drive MSC 1918 Raleigh, NC 27611-8047

http://slph.ncpublichealth.com Phone: 919-733-7308

Fax: 919-715-8611

## Certificate of Analysis

**FINAL REPORT** 

Report to: Ren Levocz

HARNETT CO ENVIRONMENTAL HEALTH

307 CORNELIUS HARNETT BLVD

LILLINGTON, NC 27546

Name of System:

Janette Adams

1949 Wade Stephenson Rd

Holly Springs, NC 27540

EIN: 566000306EH

Delivery:

**Harnett County** 

StarLiMS ID: ES240919-0092-001

Date Collected:

09/18/2024

Time Collected: 13:05

By: Ren Levocz

240448 Sample ID:

Date Received:

09/19/2024

Time Received: 10:57

By: Rachel Odom

Method: EPA 508

Sample Type:

Comment:

Raw

Sampling Point:

Well Permit #

Sample Source:

Well water

Temp. at Receipt: 8.0 °C

GPS#

Analytical method requires sample temperature of 2 - 6 degrees C upon receipt. Sample results may not be

submitted for regulatory compliance with the Safe Drinking Water Act.

### **PESTICIDES Profile**

| Analyte                   | Test Result  | Reporting Limit | Unit | Qualifier(s) |
|---------------------------|--------------|-----------------|------|--------------|
| Hexachlorocyclopentadiene | Not Detected | 0.1             | ug/L |              |
| Propachlor                | Not Detected | 0.1             | ug/L |              |
| Trifluralin               | Not Detected | 0.1             | ug/L |              |
| Hexachlorobenzene         | Not Detected | 0.1             | ug/L |              |
| Lindane                   | Not Detected | 0.1             | ug/L |              |
| Heptachlor                | Not Detected | 0.1             | ug/L |              |
| Aldrin                    | Not Detected | 0.1             | ug/L |              |
| Heptachlor epoxide        | Not Detected | 0.1             | ug/L |              |
| Dieldrin                  | Not Detected | 0.1             | ug/L |              |
| Endrin                    | Trace        | 0.1             | ug/L |              |
| Methoxychlor              | Not Detected | 0.1             | ug/L |              |
| Chlordane                 | Not Detected | 0.1             | ug/L |              |
| Toxaphene                 | Not Detected | 0.1             | ug/L |              |

11/07/2024 Report Date:

Reported By: James Parrish



# Private Well Information and Use Recommendations

For Inorganic Chemical Contaminants

| County: Harnett Sample Name: Janette Adems   |
|--|
| Sample ID #: <b>ES 240919-0012-001</b> Reviewer: <b>Rachel odom</b>  |
|  |
| TEST RESULTS AND USE RECOMMENDATIONS  1. Your well water meets federal drinking water standards <i>for inorganic chemicals</i> . Your water can be used for drinking, cooking, washing, cleaning, bathing, and showering based on the <i>inorganic chemical results only</i> . You may have other water sampling results that are not taken into account in this report.   |
| 2. The following substance(s) exceeded federal drinking water standards or the North Carolina 2L calculated health levels. The North Carolina Division of Public Health recommends that your well water not be used for drinking and cooking unless you install a water treatment system to remove the checked substance(s). However, it may be used for washing, cleaning, bathing, and showering based on the <i>inorganic chemical results only</i> . |
| □ Arsenic       □ Barium       □ Cadmium       □ Chromium       □ Copper       □ Fluoride       □ Iron         □ Lead       □ Manganese       □ Mercury       □ Nickel       □ Nitrate/Nitrite       □ Selenium       □ Silver         □ Zinc       □ Zinc       □ Nickel       □ Nitrate/Nitrite       □ Selenium       □ Silver  |
| 3. While your lead levels do not exceed federal or state standards, the North Carolina Division of Public Health has concerns with any detection of lead. Should you have any questions please contact the NC Private Well and Health Program at (919) 707 - 5900.   |
| 4. Re-sample for lead and /or copper. Take a first draw and 30-second flush sample inside the house (preferably the  |
| kitchen sink) and a first draw and 4 minutes flush sample at the wellhead to determine the source of the lead and/or copper.   |
| 5. The following substance(s) exceeded aesthetic drinking water standards. Your water can be used for drinking, cooking, washing, cleaning, bathing, and showering based on the <i>inorganic chemical results only</i> , but aesthetic problems such as bad taste, odor, staining of porcelain, etc. may occur. You may want to install a household water treatment system to address aesthetic problems.  |
| □Chloride       □Copper       □Flouride       □Iron       □Manganese         □pH       □Silver       □Sulfate       □Zinc  |
| 6. a. Sodium levels exceed the U.S. Environmental Protection Agency's (USEPA) Health Advisory level for sodium of 20 mg/l. The North Carolina Division of Public Health recommends that only individuals on no or low sodium-restricted diets not use this water for drinking or cooking. It may be used for washing, cleaning, bathing, and showering based on the <i>inorganic chemical results only</i> .   |
| □b. Your sodium level exceeds 30 mg/L and may pose aesthetic issues such as bad taste, odor, staining of porcelain, etc  |
| 7. Re-sampling is recommended inmonths, to reinvestigate   |