

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION
307 W. CORNELIUS HARNETT BLVD.
LILLINGTON, NC 27546
910-893-7547 PHONE
910-893-9371 FAX

Application for Repair

EMAIL ADDRESS: oaoji@live.com

OWNER NAME Arely Jairo (Arely Lopez) PHONE 919 608 5938

PHYSICAL ADDRESS 193 Long meadow lane

MAILING ADDRESS (IF DIFFERENT THAN PHYSICAL) _____

IF RENTING, LEASING, ETC., LIST PROPERTY OWNER NAME _____

SUBDIVISION NAME _____ LOT #/TRACT # _____ STATE RD/HWY _____ SIZE OF LOT/TRACT _____

Type of Dwelling: Modular Mobile Home Stick built Other _____

Number of bedrooms 4 Basement

Garage: Yes No Dishwasher: Yes No Garbage Disposal: Yes No

Water Supply: Private Well Community System County

Directions from Lillington to your site: Take Hwy 401 towards Fuquay, Chathamville
make left on Baptist grove RD, make left Right on
Long meadow lane

In order for Environmental Health to help you with your repair, you will need to comply by completing the following:

1. A "surveyed and recorded map" and "deed to your property" must be attached to this application. Please inform us of any wells on the property by showing on your survey map.
2. The outlet end of the tank and the distribution box will need to be uncovered and property lines flagged. After the tank is uncovered, property lines flagged, underground utilities marked, and the orange sign has been placed, you will need to call us at 910-893-7547 to confirm that your site is ready for evaluation.

Your system must be repaired within 30 days of issuance of the Improvement Permit or the time set within receipt of a violation letter. (Whichever is applicable.)

By signing below, I certify that all of the above information is correct to the best of my knowledge. False information will result in the denial of the permit. The permit is subject to revocation if the site plan, intended use, or ownership changes.

Arely Jairo
Owner Signature

10/4/24
Date

HOMEOWNER INTERVIEW FORM

It is important that you answer the following questions for our inspectors. Please do not leave any blanks if possible, and answer all questions to the best of your ability. Thank You.

Have you received a violation letter for a failing system from our office? [] YES [X] NO

Also, within the last 5 years have you completed an application for repair for this site? [] YES [X] NO

Year home was built (or year of septic tank installation) 3/2022

Installer of system Jason Matthews

Septic Tank Pumper _____

Designer of System _____

1. Number of people who live in house? 2 # adults 1 # children 3 # total

2. What is your average estimated daily water usage? _____ gallons/month or day _____ county water. If HCPU please give the name the bill is listed in Aray Saco

3. If you have a garbage disposal, how often is it used? [] daily [] weekly [] monthly N/A

4. When was the septic tank last pumped? N/A How often do you have it pumped? _____

5. If you have a dishwasher, how often do you use it? [] daily N/A [] every other day [] weekly

6. If you have a washing machine, how often do you use it? [] daily [] every other day [X] weekly [] monthly

7. Do you have a water softener or treatment system? [] YES [X] NO Where does it drain? _____

8. Do you use an "in tank" toilet bowl sanitizer? [] YES [X] NO

9. Are you or any member in your household using long term prescription drugs, antibiotics or chemotherapy? [] YES [X] NO If yes please list _____

10. Do you put household cleaning chemicals down the drain? [] YES [X] NO If so, what kind? _____

11. Have you put any chemicals (paints, thinners, etc.) down the drain? [] YES [X] NO

12. Have you installed any water fixtures since your system has been installed? [] YES [X] NO If yes, please list any additions including any spas, whirlpool, sinks, lavatories, bath/showers, toilets _____

13. Do you have an underground lawn watering system? [] YES [X] NO

14. Has any work been done to your structure since the initial move into your home such as, a roof, gutter drains, basement foundation drains, landscaping, etc? If yes, please list NO

15. Are there any underground utilities on your lot? Please check all that apply: [X] Power [] Phone [X] Cable [] Gas [] Water

16. Describe what is happening when you are having problems with your septic system, and when was this first noticed?

Septic inspection performed by potential buyer after hurricane showed standing water near drainage lines

17. Do you notice the problem as being patterned or linked to a specific event (i.e., wash clothes, heavy rains, and household guests?) [] YES [] NO If Yes, please list have not seen

this problem before.

Harnett County Department of Public Health

Operation Permit

PERMIT # 5FD2110-021

New Installation Septic Tank Nitrification Line Repair Expansion SL1427

PROPERTY LOCATION: 193 LONG MEADOW (BAPTIST CHURCH RD)

Name: (owner) D.L. HORTON, INC. SUBDIVISION LAFATETTE MEADOWS LOT # 17


System Installer: JASON MATTHEWS

Basement with plumbing: Garage Number of Bedrooms 4
 Type of Water Supply: Community Public Well Distance from well NA feet

System Type: 256 REDUCED SIZE S.T.S. III Types V and VI Systems expire in 5 years.

(In accordance with Table V a) Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961.
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: As required by Rule .1961. Other: _____
 Subsurface system operator required? Yes No
 If yes, see attached sheet for additional operation conditions, maintenance and reporting.
- IV. Operation: _____
- V. Other: _____

D-Box Pump Alarm H2O Line PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: Conventional Other EZ FLOW III Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface No. of exact length width of depth of
 Drainage Field ditches 4 of each ditch 100 feet ditches 3 feet ditches 20-24 inches
 French Drain Required: _____ Linear feet

Authorized State Agent: [Signature] Date 03/22/2022

Harnett County Department of Public Health Improvement Permit

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: 193 Long Meadow Ln. (Baptist Grove Rd.)
SUBDIVISION Lafayette Meadows LOT # 17

ISSUED TO: D.R. Horton Inc.

NEW REPAIR EXPANSION

Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: 46x38 (4bed/2.5ba) SFD

Proposed Wastewater System Type: 25% Reduction Sys.

Projected Daily Flow: 480 GPD

Number of bedrooms: 4 Number of Occupants: 8 max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well NA feet

Permit valid for: Five years
 No expiration

Permit conditions:

Authorized State Agent: [Signature] Date: 11/22/2021 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules 1950, 1952, 1954, 1955, 1956, 1957, 1958, and 1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: D.R. Horton Inc.

PROPERTY LOCATION: 193 Long Meadow Ln. (Baptist Grove Rd.)
SUBDIVISION Lafayette Meadows LOT # 17

Facility Type: 46x38 (4bed/2.5ba) SFD New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** 25% Reduction System (Initial) Wastewater Flow: 480 GPD

(See note below, if applicable)

25% Reduction System (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons

Pump Tank Size _____ gallons

Number of trenches 4

Exact length of each trench 100 feet

Trenches shall be installed on contour at a

Maximum Trench Depth of: 18-24 inches

(Trench bottoms shall be level to +/- 1/4"

in all directions)

Trench Spacing: 9 Feet on Center

Soil Cover: 6-12 inches

(Maximum soil cover shall not exceed

36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs _____ GPM

Aggregate Depth: NA inches below pipe

NA inches above pipe

NA inches total

Conditions: Proposal by Hal Owens Assoc. Inc.,

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____

Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature]

Date: 11/22/2021

ANDREW OWENS

Construction Authorization Expiration Date: 11/22/2026

Application # SFD2110-0121

Harnett County Department of Public Health Site Sketch

Property Location: 193 Long Meadow Ln. (Baptist Grove Rd. - SR 1427)

Issued To: D.R. Horton Inc.


Subdivision Lafayette Meadows

Lot # 17

Authorized State Agent: _____


Andrew Coward

Date: 11/22/2021



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.


Lot 17, Lafayette Meadows Subdivision



Lines flagged at site on 9-ft centers.

Line #	Color	Relative	Drainline
		Elevation (ft)	Length(ft)
1	R	101.28	133
2	Y	101.08	133
3	B	100.97	133
4	R	100.82	100
5	B	100.62	100
6	W	100.29	100
7	Y	100.04	100
Benchmark		100.00	



Scale 1 in = 50 ft

 Distances are paced
 and approximate.
 Not a survey.


This design represents our professional opinion but does not guarantee or represent permit approval by the Health Department.

4 bedroom home (480 gal/day)
Initial System
 Gravity to 4 X 100ft
 Accepted Status System (25% reduction drainlines)
 installed off contour at 18-24 inch trench depth
 LTAR 0.3 gal/day/sqft
Repair System
 Pump to 3 X 133ft
 Accepted Status System (25% reduction drainlines)
 installed on contour at 18-24 inch trench depth
 LTAR 0.3 gal/day/sqft



REFERENCES:

- DB 825, PG 991
 - DB 1802, PG 482
 - DB 2109, PG 580
 - DB 2366, PG 797
 - DB 2794, PG 615
 - DB 2951, PG 602
 - DB 3896, PG 63
 - DB 3894, PG 626
 - PC 6, PG 98
 - PB 2007, PG 337
 - PB 2016, PG 126
- AN UNRECORDED MAP,
PREPARED BY
MALDIN - WATKINS
SURVEYING, P.A.
DATED JULY 11, 2019




N/E
KELLY G. MCNEE
PIN: 0653-19-7501
DB 2366, PG 797
PB 2007, PG 337

N/E
CARY TOLAR
PIN: 0653-39-5515
DB 825, PG 991

LEGEND

- | | | | |
|--|--|--|----------------------|
| | LINE SURVEYED | | PROPOSED WATER VALVE |
| | LINE NOT SURVEYED | | EXISTING POND |
| | EXISTING WETLANDS | | EXISTING WETLANDS |
| | PROPOSED UNDERGROUND WATERLINE (6" MAIN/3/4" SERVICES) | | LOT NUMBER |
| | PROPOSED STREETSCAPE TREES | | IRON PIPE FOUND |
| | PROPOSED STREET LIGHTS | | IRON REBAR FOUND |
| | PROPOSED FIRE HYDRANT | | IRON PIPE SET |
| | PROPOSED WATER METER | | COMPUTED POINT |



**MAJOR SUBDIVISION PLAT
FOR
LAFAYETTE MEADOWS**

PIN: 0653-29-8668
DB 3894, PG 626
HECTORS CREEK TOWNSHIP
HARRIETT COUNTY, NORTH CAROLINA

NORIS # 1100

FILE NO. NS201090	BOHLER			1330 PARKLAW AVENUE, SUITE 130 RALEIGH, NORTH CAROLINA 27615-7100 www.bohlerinc.com		
DATE 10/13/2021						
FIELD DATE 10/28/2020	CREW CHIEF BS	DRAWN RJ	REVIEWED TET	APPROVED TET	SCALE 1"=80'	SHEET 3 OF 4

SEE SHEET 1 FOR NOTES, CERTIFICATIONS, AND CURVE AND LINE TABLES

BOHLER ENGINEERS, ALL RIGHTS RESERVED. NO PART OF THIS DOCUMENT IS TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, WITHOUT THE WRITTEN PERMISSION OF BOHLER ENGINEERS, INC.


COMMENTS: _____

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTLY STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT	0.6 - 0.3		NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			

- STRUCTURE
 SG-SINGLE GRAIN
 M- MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

- MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, references or benchmark, and North)



Matthew S. Willis Register of Deeds
Harnett County, NC
Electronically Recorded
06/29/2022 10:47:40 AM NC Rev Stamp: \$850.00
Book: 4156 Page: 2911 - 2912 (2) Fee: \$26.00
Instrument Number: 2022103906

HARNETT COUNTY TAX ID #
080643 0033 20

06-29-2022 BY: TC

NORTH CAROLINA SPECIAL WARRANTY DEED

Prepared by: Summer Rich, 3000 Aerial Center Parkway, Suite 100, Morrisville, NC 27560
Grantee's address (return to): 193 Long Meadow Lane, Fuquay Varina, NC 27526

NORTH CAROLINA
HARNETT COUNTY

Revenue Stamps: \$850

Parcel ID#: 080643 0033 20

This Deed is made this 28th day of June, 2022, by and between **D.R. HORTON, INC., a Delaware corporation**, with address of 8001 Arrowridge Blvd., Charlotte, NC 28273, hereinafter called "Grantor," and **ARELY D. LOPEZ and RICARDO ERNESTO RODRIGUEZ JACO, a married couple**, whose address is 193 Long Meadow Lane, Fuquay Varina, NC 27526, hereinafter called "Grantee."

WITNESSETH:

That the Grantor, for a valuable consideration paid by the Grantee, the receipt of which is hereby acknowledged, has given, granted, bargained, sold and conveyed, and by these presents does give, grant, bargain, sell and convey unto the Grantee, its successors and assigns, all that certain tract of real estate located in HARNETT County, North Carolina, and more fully described as follows:

BEING all of Lot 17, Lafayette Meadows Subdivision, per plat and survey thereof recorded in Plat Book 2021, Pages 460 through 463, inclusive, Harnett County Registry, to which plat reference is hereby made for a more particular description of same.

The property described herein does not include the primary residence of Grantor.

TO HAVE AND TO HOLD the above described tract of real estate, with all privileges and appurtenances thereunto belonging, to the Grantee in fee simple.

And the Grantor covenants with the Grantee, that Grantor has done nothing to impair such title as Grantor received, and Grantor will warrant and defend the title against lawful claims of persons claiming, by, under or through Grantor, other than the following exceptions:

1. Ad valorem taxes for the year 2022 and subsequent years.
2. Restrictive covenants, utility easements and rights-of-way of record.
3. Any and all matters shown on the recorded plat(s).

Submitted electronically by "Bagwell Holt Smith P.A."
in compliance with North Carolina statutes governing recordable documents
and the terms of the submitter agreement with the Harnett County Register of Deeds.

IN WITNESS WHEREOF, the Grantor has hereunto set his hand and seal, or if corporate, has caused this Deed to be signed in its corporate names by its duly authorized officers and its seal to be hereunto affixed by authority of their Boards of Directors, the day and year first above written.

D.R. HORTON, INC.,
A Delaware corporation

By: *Melissa M. Guy*
Melissa M. Guy, Assistant Secretary

NORTH CAROLINA

WAKE COUNTY


I, Jeffrey A. Jones, a notary public, do hereby certify that Melissa M. Guy personally came before me this day and acknowledged that she is an Assistant Secretary of D.R. Horton, Inc., a Delaware corporation, and that she, as an Assistant Secretary, being duly authorized to do so, executed the foregoing on behalf of the corporation.

Witness my hand and official seal this the 28th day of June, 2022.

My commission expires: 3.20.2026

Jeffrey A. Jones
Jeffrey A. Jones, Notary Public

(Affix Notary Seal)



Septic System Inspection Report

*193 Long Meadow Lane
Fuquay-Varina, N.C. 27526*



Prepared For:

Hedaiah Tolbah, Ahmed Mustafa (Realtor)

Prepared By:

Carson Lynn, Lynn Environmental Consulting

Inspector License # 53661

Inspection Date:

September 30, 2024

On September 30, 2024, Lynn Environmental Consulting personnel inspected the septic system serving a residence located at 193 Long Meadow Lane in Fuquay-Varina, North Carolina. A copy of the original septic permit was obtained from Harnett County Environmental Health Department. The septic system is permitted for a 4-bedroom home. The residence is served by public water supply. A copy of the septic permit, inspection checklist, and pictures taken during inspection follow this report.

Septic Tank

The septic tank is located on the south side of the residence. The septic tank inlet compartment measured 8 feet from the foundation of the house. The septic tank inlet and outlet lids were located underneath round, plastic access risers and were opened for inspection. The septic tank lids and riser lids were intact. At the time of inspection, water level in the tank measured approximately 48" in the inlet compartment of the tank and 50" in the outlet compartment of the tank. Solids in the inlet end of the tank measured approximately 8". Solids in the outlet end of the tank measured 14". The PVC outlet tee was found intact and it contained a filter. The filter was found dirty and was cleaned during the inspection. The baffle wall was found intact.

Dispersal Field

The dispersal field is located approximately 24 feet from the pump tank. The dispersal field is gravity fed by a distribution box to four accepted-status, EZ-Flow trenches, each 100 feet in length. Four EZ-Flow trenches were located when probing the dispersal field. There was evidence of surfacing effluent in the dispersal field while probing to locate the trenches. The distribution box was located below ground surface and was excavated for inspection. High water was observed in the distribution box and did not appear to be flowing properly out of the box. Two drainage easements were located on the two property lines near the dispersal field. Surface water appeared to pool above the dispersal field. Pooling surface water appears to be saturating the dispersal field.

Conclusions

The septic tank consisted of approximately 28% solids in the outlet compartment. It is recommended that septic tanks are pumped and cleaned when the solids in the tank are 25-33% of the tank's capacity.

Surface water appeared to be pooling on the dispersal field. The drainage appeared to be affecting the condition and/or function of the dispersal field.

No representation, warranties or opinions are hereby given, written or expressed otherwise, as to the future performance of onsite wastewater system described herein. This onsite wastewater system inspection is a presentation of system facts in place on date of inspection.

We appreciate the opportunity to serve you.

Sincerely,



Carson Lynn

Lynn Environmental Consulting

On-Site Wastewater Inspection

Property Address 193 Long Meadow Lane
Fuquay-Varina, N.C. 27526

Client Name Hedaiah Tolbah Ahmed Mustafa (Realtor)

Current Owner of Record Arely Lopez

Date of Inspection September 30, 2024

4 Advertised number of bedrooms as stated in MLS or as stated in attached sworn statement by owner or owner's representative

480 Gallons per day for designed system or number of bedrooms as stated in available local health department information

Yes Inspection shall include any part of the system located more than 5 feet from the primary structure that is a part of the Operations Permit

Yes Copy of Operations Permit from Johnston County Environmental Health Attached

N/A Operations Permit not available

N/A System requires a Certified Subsurface Water Pollution Control System Operator pursuant to G.S. 90A

Current Operator's Name N/A

Most recent performance, operation and maintenance reports are:
N/A Attached

Type of Water Supply: Public Water Supply

Location of Septic Tank and Septic Tank Details:

South Location of septic tank _____

8 Feet from house or structure _____

N/A Feet from well, if applicable _____

N/A Feet from water line, if applicable and readily visible _____

10+ Feet from property line, if said property lines are known _____

Yes Access riser(s)
 Describe: Round, plastic. Good, intact.

2-3" Distance from finished grade to top of access riser _____

Yes Access riser lids intact _____

4-5" Distance from finished grade to top of tank _____

Yes Tank lids intact _____

Yes Tank has baffle wall
 Describe condition of baffle wall: Unable to determine integrity of wall, pumping declined

Yes Inflow to tank is noted as sufficient _____

No Inflow to tank is noted as insufficient or blocked _____

Yes Water level in tank is relative to tank outlet _____

Yes Outlet T is present
 Describe condition of Outlet T: PVC. Good, intact.

Yes Outlet has filter
 Describe condition of filter: Dirty, cleaned during the inspection.

Yes Effluent leaves the outlet _____

No Roots present in tank
 Describe extent of roots: _____

No Evidence of tank leakage
 Describe: _____

No Evidence of non-permitted connections, such as downspouts or sump pumps

Yes	Connection present from house to tank	
Yes	Connection present from tank to next component	
28%	Percentage of solids in tank. (Septic tanks should be pumped out between 25-33%)	
	Inlet measurement	8/48" Outlet measurement 14/50"
N/A	Unable to locate tank. System inspection cannot be completed until tank is located.	
	Date tank was last pumped	Unknown

Pump Tank

N/A	Location of pump tank	
N/A	Feet from house or structure	
N/A	Feet from well or spring, if applicable	
N/A	Feet from water line, if applicable	
N/A	Feet from property line, if property lines are known	
N/A	Feet from septic tank	
	Access risers in place	N/A
	Describe type of access risers:	N/A
	Describe condition of tank lids:	N/A
	Location of control panel:	N/A
	Condition of control panel:	N/A
N/A	Audible alarm (as applicable) works	
N/A	Visible alarm (as applicable) works	
N/A	Pump turns on and effluent is delivered to next component	
N/A	Unable to operate pump due to lack of electricity at site at time of inspection	

Dispersal Field

Type of System:

Accepted-Status, EZ-Flow Trenches

Brief Description of System Type:

Gravity Feed to Equal Distribution

10+	Feet from property line, if property lines are known	
24	Feet from septic/pump tank	
	Location:	Backyard
4	# of lines	
100'	Length of Lines	
Yes	Evidence of past or current surfacing at time of inspection. Describe:	
	Surfacing effluent while probing	
	House Status:	
No	Evidence of traffic over the dispersal field	
Yes	Vegetation, grading and drainage noted that may affect the condition of the system	
	Surface water drainage easements near dispersal field, pooling water in fields	
Yes	Effluent is reaching the dispersal field	

Distribution

	Type of Distribution Device:	Concrete Distribution Box
	Describe condition of distribution device:	Good, intact.
Yes	Inflow to distribution device(s) is noted as sufficient	
No	Inflow to distribution device(s) is noted as insufficient or blocked	

Inspector Name: Carson Lynn
Certification # 53661
Address 7713 Pegram Street, Willow Spring, N.C. 27592
Phone 919-753-3559

No representation, warranties or opinions are hereby given, written or expressed otherwise, as to the future performance of onsite wastewater system described herein. This onsite wastewater system inspection is a presentation of system facts in place on date of inspection.

Inspector Signature:  **Date** September 30, 2024