

Harnett County Environmental Health

File/Permit Number: EH2412-0004

CONSTRUCTION AUTHORIZATION

County: Harnett PIN/Lot Identifier: 1518-65-2636.000 Lot 8
Owner: AGNEW PAT M Applicant: AGNEW PAT M
Property Location: 154 STEWART MASON DR DUNN, NC 28334
Facility Type: EX. DW

Number of bedrooms: 4 Number of Occupants: 8 Other: Currently is a 3-BR Expanding to a 4-BR
 New Expansion Repair System Relocation Change of Use
Basement? Yes No Basement Fixtures? Yes No
Crawl Space? Yes No Slab Foundation? Yes No
Type of Wastewater System* Ex. Conventional System (Initial) Low Profile Chambers System (Repair)

**Please include system classification for proposed wastewater system types in accordance with Rule .1301 Table XXXII*

Design Daily Flow: 480 GPD Wastewater Strength: Domestic High Strength Industrial Process Wastewater
Rule .0403(e) Engineering Design Utilizing Low-flow Fixtures and Low-flow Technologies (S.L. 2013-413 and 2014-120)? Yes No
(if yes, please provide engineering documentation)

Effluent Standard: DSE HSE NSF/ANSI 40 TS-I TS-II RCW
Type of Water Supply: Private well Public well Shared well Municipal Supply Spring Other: _____

Installation Requirements/Conditions

Septic Tank Size: Ex. 1,000 gallons Total Trench/Bed Length: 450' feet Trench/Bed Spacing: 9' feet on center
Trench/Bed Width: 36" inches LTAR: .35 gpd/ft² Usable Depth to LC (Initial)*: 27" ^{Limiting condition}
Soil Cover: 6" inches Slope Corrected Maximum Trench/Bed Depth†: 15" inches ^{* Measured on the downhill side of the trench}
Pump Tank Size (if applicable): Ex. 1,000 gallons Requires more than one pump? Yes No
Pump Requirements: _____ ft. TDH vs. _____ GPM Grease Trap Size (if applicable): _____ gallons
Distribution Method: Serial D-Box or Parallel Pressure Manifold(s) LPP Other: Need 480' of conventional or 450' with added Accepted 25%
Artificial Drainage Required: Yes No If yes, please specify details: _____

Legal Agreements (If the answer is "Yes" to any type of legal agreements, please attach a copy of the agreement.)

Multi-party Agreement Required [Rule .0204(g)]: Yes No
Easement, Right-of-Way, or Encroachment Agreement Required [Rule .0204(d)]: Yes No
Declaration of Restrictive Covenants: Yes No Pre-Construction Conference Required: Yes No
Management Entity Required: Yes No Minimum O&M Requirements: _____
Conditions: Ex. 360'(3 - 120' Lines) Adding a 4th Line, either 120' of conventional or 90' of 25% accepted product).
Must Add a Filter to Septic Tank & Replace D-Box.

The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached site sketch. This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be affected by a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of 15A NCAC 18E, or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit.

Authorized Agent's Printed Name: Ren Levocz Expiration Date: 1-7-30
Authorized Agent's Signature:  Date: 1-7-25

See attached site sketch

Harnett County Environmental Health

SITE SKETCH

PIN 1518-65-2636.000

Permit Number EH2412-0004

AGNEW PAT M

Applicant's Name

Pat M Agnew

Authorized State Agent

Lot 8

Subdivision/Section/Lot Number

1-7-25

Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

Scale = NTS

