

Harnett County Department of Public Health

PERMIT # EH 2501-0023

Operation Permit

☐ New Installation ☒ Septic Tank ☒ Nitrification Line ☒ Repair ☐ Expansion

PROPERTY LOCATION: 31 Ashton LN, Angier

Name: (owner) Mark & Alison Combs

SUBDIVISION Pinecroft

LOT # 19

System Installer: Varner Septic

Basement with plumbing: ☐ Garage ☒ Number of Bedrooms 3


Type of Water Supply: ☐ Community ☒ Public ☐ Well Distance from well _____ feet

System Type: 25% Reduction Type III (b) In4 chamber Types V and VI Systems expire in 5 years.

(In accordance with Table V a)

Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961. Ashton LN
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: As required by Rule .1961. Other: _____
- Subsurface system operator required? Yes ☐ No ☐
- If yes, see attached sheet for additional operation conditions, maintenance and reporting.

- IV. Operation: _____
- V. Other: _____

☐ _____ D-Box ☐ _____ Pump ☐ _____ Alarm ☐ _____ H2O Line ☐ _____ PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: ☐ Conventional ☒ Other Type III (b) In4 chamber Septic Tank: ex 1,000 gallons Pump Tank: 1,000 gallons

Subsurface No. of exact length width of depth of

Drainage Field ditches 3 of each ditch 90' feet ditches 3' feet ditches 20' inches

French Drain Required: _____ Linear feet

Authorized State Agent Mark & Alison Combs

Date 3-18-23