

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550

fax: 910-893-9429

April 15th, 2025

Jorge Granados
186 D'Ango Cirlee
Angier, NC 27501

Re: Status of Repair Application

Mr. Granados

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- ☐ 1. Use pink flags to mark property lines and irons that are
Set by surveyor need to be visible. Property lines to be marked/flagged every 50'.
- ☐ 2. Use orange flags to mark house box.
- ☐ 3. Directions not clear to property (\$25.00 fee incurred)
- ☐ 4. Property needs cleared
- ☐ 5. Driveway not shown on site plan (Revision Required)
- ☐ 6. Backhoe pits required

☒ 7. Other- No sign of failure or sewage was detected. Septic Lines were dry near the end. Spoke with Applicant and discussed the following.
Recommended to have a septic contractor re-level the d-Box, Run a camera through lines to determine if there is a blockage. Try jetting the out if needed.
Witnessed that the plumbing to the tank had a small continuous drip entering the tank. May be a running toilet or small leak.

Your application will be put on hold until the selected items above have been addressed.
Any questions I can be reached at 910-893-7547 between 8:00am -9:00am Monday-Friday.

Sincerely,



Reynold Levocz R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health