

HARNETT COUNTY ENVIROMENTAL HEALTH

File/Permit #: EH2505-0012

IMPROVEMENT PERMIT (IP) CDP #:	
New ☐ Expansion ☐ Repair ☐ System Relocation ☐ Change of Use	
Owner: Applicant:	
Property Location: PIN/Lot Identifier:	
Subdivision:	
Facility Type: Number of bedrooms: Number of Occupants: Other:	
Design Daily Flow: GPD LTAR (Initial): gpd/ft² LTAR (Repair): gpd/ft²	
Wastewater System Type: (Initial)	
Pump Required: Yes No May be required Usable Depth to Limiting Condition (Initial):	
Wastewater System Type (Repair)	
Pump Required: Yes No May be required Usable Depth to Limiting Condition (Repair):	
Effluent Standard: DSE HSE Other: Type of Water Supply: Private well Municipal Supply Other:	
Permit conditions:	
The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This permit is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.	ne site.
Authorized Agent's Printed Name: Ren Levocz Date:	—
Authorized Agent's Signature: Expiration Date:	-
New ☐ Expansion ☐ Repair Owner: WEISS JASON M & WEISS BRITTANY P Property Location: 705 PINEY GROVE RAWLS RD FUQUAY-VARINA, NC 27526 Subdivision: ☐ System Relocation ☐ Change of Use Applicant: WEISS JASON M & WEISS BRITTANY P PIN/Lot Identifier: 0655-24-2624.000 Lo 3 Lot #: 3 Block: ☐ Section: ☐ Change of Use Applicant: WEISS JASON M & WEISS BRITTANY P PIN/Lot Identifier: 0655-24-2624.000 Lo 3	
Facility Type: EX. SFD Number of bedrooms: 3 Number of Occupants: 6 Other:	
Design Daily Flow: 360 GPD LTAR:3 gpd/ft²	
Effluent Standard: DSE HSE Other: Type of Water Supply: Private well Municipal Supply Other:	
Installation Requirements/Conditions Wastewater System Type: 25% Reduction System Pump Required: ■ Yes □ No □ May be requ	ina d
Septic Tank Size: Ex. 1,000 gallons Total Trench Length: 320 feet Trench Spacing: 9' feet on center Maximum Trench Depth: 18"-22" inches Trench Width: 36" inches Distribution Method: Serial D-Box or Parallel Pressure Manifold Other: 4-80	
Artificial Drainage Required: Yes No I If yes, please specify details:	
Management Entity Required: Yes No Minimum O&M Requirements:	
Permit conditions:	
Reroute Water Line to be 10' Off Septic as Shown on Permit.	
The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached site sketch. <u>This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes.</u> The Construction Authorization shall not be affected by a change in owners the site. This Construction Authorization is subject to compliance with the provisions of 15A NCAC 18E, or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit Authorized Agent's Printed Name: Ren Levocz Date:	
Authorized Agent's Signature:	
Owner/Legal Representative Signature: Date:	

SITE SKETCH

0655-24-2624.000

Permit Number EH2505-0012

WEISS J	ASON I	M &	WEISS	BRITT	ANY	Ρ
---------	--------	-----	-------	-------	-----	---

Applicant's Name

Ren Levocz

Authorized State Agent

Lot 3

Subdivision/Section/Lot Number

6.9- 25

Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the * Each Flagged Line is approximately 100'. Only Need a total of 320' installation to ensure that the proper grade is maintained.

Scale = NTS

Build 0/2 * Water Line Must be reconted to be 10' off any part of septic