

**HARNETT COUNTY ENVIROMENTAL HEALTH**

File/Permit #: EH2506-0001

CDP #:

IMPROVEMENT PERMIT (IP)☐ New ☐ Expansion ☐ Repair ☐ System Relocation ☐ Change of Use

Owner: _____

Applicant: _____

Property Location: _____

PIN/Lot Identifier: _____

Subdivision: _____

Lot #: _____ Block: _____ Section: _____

Facility Type: _____ Number of bedrooms: _____ Number of Occupants: _____ Other: _____

Design Daily Flow: _____ GPD LTAR (Initial): _____ gpd/ft² LTAR (Repair): _____ gpd/ft²

Wastewater System Type: _____ (Initial)

Pump Required: ☐ Yes ☐ No ☐ May be required Usable Depth to Limiting Condition (Initial): _____

Wastewater System Type: _____ (Repair)

Pump Required: ☐ Yes ☐ No ☐ May be required Usable Depth to Limiting Condition (Repair): _____Effluent Standard: ☐ DSE ☐ HSE ☐ Other: _____ Type of Water Supply: ☐ Private well ☐ Municipal Supply ☐ Other: _____

Permit conditions:

The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This permit is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.

Authorized Agent's Printed Name: Ren Levocz

Date: 06/09/2025

Authorized Agent's Signature: _____

Expiration Date: _____

CONSTRUCTION AUTHORIZATION (CA)☐ New ☐ Expansion ☒ Repair ☐ System Relocation ☐ Change of Use

Owner: GAFA JEAN VALERIE & GAFA CHARLES JOSEPH

Applicant: GAFA JEAN VALERIE & GAFA CHARLES JOSEPH

Property Location: 5069 COKESBURY RD FUQUAY VARINA, NC 27526

PIN/Lot Identifier: 0635-23-6965.000

Subdivision: _____

Lot #: _____ Block: _____ Section: _____

Facility Type: Ex. SFD Number of bedrooms: 2 Number of Occupants: 4 Other: _____

Design Daily Flow: 240 GPD LTAR: --- gpd/ft²Effluent Standard: ☒ DSE ☐ HSE ☐ Other: _____ Type of Water Supply: ☐ Private well ☒ Municipal Supply ☐ Other: _____**Installation Requirements/Conditions**Wastewater System Type: EX. (Replacing Tank) Pump Required: ☐ Yes ☐ No ☒ May be required

Septic Tank Size: 1,000 gallons Total Trench Length: --- feet Trench Spacing: --- feet on center

Pump Tank Size: 1,000 gallons Maximum Trench Depth: --- inches Soil Cover: 6" inches

Trench Width: --- inches Distribution Method: ☐ Serial ☒ D-Box or Parallel ☐ Pressure Manifold ☐ Other: _____Artificial Drainage Required: Yes ☐ No ☐ If yes, please specify details: _____Management Entity Required: ☐ Yes ☐ No Minimum O&M Requirements: _____

Permit conditions:

Replace Tank and Distribution Box. May Require a Pump Tank if Supply Line from Septic Tank to D-Box does not have proper Fall.

The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached site sketch. This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be affected by a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of 15A NCAC 18E, or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit.

Authorized Agent's Printed Name: Ren Levocz

Date: 06/09/25

Authorized Agent's Signature: _____

Expiration Date: 06/09/2030

Owner/Legal Representative Signature: _____

Date: _____

***See attached site sketch**

Harnett County Environmental Health

SITE SKETCH

PIN 0635-23-6965.000

Permit Number EH2506-0001

GAFA JEAN VALERIE & GAFA CHARLES JOSEPH

Applicant's Name

Ren Levocz


Authorized State Agent

Subdivision/Section/Lot Number

06/09/2025

Date _____

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

Scale = NTS

NCDHHS/DPH/EHS/OSWP

Cokes Bury Rd

Revised January 2024
Form IP-24.1