



HARNETT COUNTY ENVIROMENTAL HEALTH

File/Permit #: EH2507-0011/EH2507-0012

CDP #: _____

IMPROVEMENT PERMIT (IP)

☐ New ☐ Expansion ☐ Repair ☐ System Relocation ☐ Change of Use

Owner: _____ Applicant: _____

Property Location: _____ PIN/Lot Identifier: _____

Subdivision: _____ Lot #: _____ Block: _____ Section: _____

Facility Type: _____ Number of bedrooms: _____ Number of Occupants: _____ Other: _____

Design Daily Flow: _____ GPD LTAR (Initial): _____ gpd/ft² LTAR (Repair): _____ gpd/ft²

Wastewater System Type: _____ (Initial)

Pump Required: ☐ Yes ☐ No ☐ May be required Usable Depth to Limiting Condition (Initial): _____

Wastewater System Type: _____ (Repair)

Pump Required: ☐ Yes ☐ No ☐ May be required Usable Depth to Limiting Condition (Repair): _____Effluent Standard: ☐ DSE ☐ HSE ☐ Other: _____ Type of Water Supply: ☐ Private well ☐ Municipal Supply ☐ Other: _____

Permit conditions: _____

The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This permit is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.

Authorized Agent's Printed Name: Mark Osborne REHS Date: 07/23/2025

Authorized Agent's Signature: _____ Expiration Date: _____

CONSTRUCTION AUTHORIZATION (CA)

☐ New ☐ Expansion ☒ Repair ☐ System Relocation ☐ Change of Use

Owner: Roots Management Applicant: Roots Management

Property Location: 30 S Brenda & 35 S Peggy PIN/Lot Identifier: 0515-50-4630

Subdivision: Anderson Creek MHP Lot #: _____ Block: _____ Section: _____

Facility Type: (2) SWMH Number of bedrooms: 4 Number of Occupants: 8 Other: _____

Design Daily Flow: 480 GPD LTAR: .7 gpd/ft²Effluent Standard: ☒ DSE ☐ HSE ☐ Other: _____ Type of Water Supply: ☐ Private well ☒ Municipal Supply ☐ Other: _____

Installation Requirements/Conditions

Wastewater System Type: 25% reduction Pump Required: ☐ Yes ☐ No ☒ May be required

Septic Tank Size: Existing gallons Total Trench Length: 170 feet Trench Spacing: 9 feet on center

Pump Tank Size: _____ gallons Maximum Trench Depth: 28 inches Soil Cover: 6 inches

Trench Width: 36 inches Distribution Method: ☒ Serial ☐ D-Box or Parallel ☐ Pressure Manifold ☐ Other: _____Artificial Drainage Required: Yes ☐ No ☒ If yes, please specify details: _____Management Entity Required: ☐ Yes ☒ No Minimum O&M Requirements: _____

Permit conditions: _____

The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached site sketch. This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be affected by a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of 15A NCAC 18E, or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit.

Authorized Agent's Printed Name: Mark Osborne REHS Date: 07/23/25

Authorized Agent's Signature: _____ Expiration Date: 07/23/2030

Owner/Legal Representative Signature: _____ Date: _____

*See attached site sketch

Harnett County Environmental Health

SITE SKETCH

PIN 0515-50-4630

Permit Number EH2507-0011/EH2507-0012

Roots Management

Anderson Creek MHP

Applicant's Name

Subdivision/Section/Lot Number

Mark Osborne REHS

07/23/2025

Authorized State Agent

Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

Scale = NTS

