



HARNETT COUNTY ENVIRONMENTAL HEALTH

File/Permit #: E42509-0010

CDP #: _____

IMPROVEMENT PERMIT (IP)

☒ New ☐ Expansion ☐ Repair ☐ System Relocation ☐ Change of UseOwner: Jacob + Jaimie Gardner Applicant: _____Property Location: 125 Still Branch Path Angier PIN/Lot Identifier: _____Subdivision: Ray Wayne Gardner Lot #: 1 Block: _____ Section: _____Facility Type: SFD Number of bedrooms: 4 Number of Occupants: 8 Other: _____Design Daily Flow: 480 GPD LTAR (Initial): .4 gpd/ft² LTAR (Repair): .4 gpd/ft²Wastewater System Type: 25% Reduction (Initial)Pump Required: ☐ Yes ☐ No ☒ May be required Usable Depth to Limiting Condition (Initial): 42Wastewater System Type: 25% Reduction (Repair)Pump Required: ☐ Yes ☐ No ☒ May be required Usable Depth to Limiting Condition (Repair): 42Effluent Standard: ☐ DSE ☐ HSE ☐ Other: _____ Type of Water Supply: ☐ Private well ☐ Municipal Supply ☐ Other: _____

Permit conditions:

The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This permit is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.

Authorized Agent's Printed Name: JAMES E. Markham REHS Date: 8-5-25Authorized Agent's Signature: James E. Markham REHS Expiration Date: 8-5-30

CONSTRUCTION AUTHORIZATION (CA)

☒ New ☐ Expansion ☐ Repair ☐ System Relocation ☐ Change of UseOwner: Jacob + Jaimie Gardner Applicant: _____Property Location: 125 Still Branch Path Angier N.C. PIN/Lot Identifier: _____Subdivision: Ray Wayne Gardner Lot #: 1 Block: _____ Section: _____Facility Type: SFD Number of bedrooms: 4 Number of Occupants: 8 Other: _____Design Daily Flow: 480 GPD LTAR: .4 gpd/ft²Effluent Standard: ☒ DSE ☐ HSE ☐ Other: _____ Type of Water Supply: ☐ Private well ☒ Municipal Supply ☐ Other: _____

Installation Requirements/Conditions

Wastewater System Type: 25% Reduction System Pump Required: ☐ Yes ☐ No ☐ May be requiredSeptic Tank Size: 1000 gallons Total Trench Length: 300 feet Trench Spacing: 9 feet on centerPump Tank Size: _____ gallons Maximum Trench Depth: 22 inches Soil Cover: 6 inchesTrench Width: 3 inches Distribution Method: ☐ Serial ☒ D-Box or Parallel ☐ Pressure Manifold ☐ Other: _____Artificial Drainage Required: Yes ☐ No ☒ If yes, please specify details: _____Management Entity Required: ☐ Yes ☒ No Minimum O&M Requirements: _____

Permit conditions:

The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached site sketch. This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be affected by a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of 15A NCAC 18E, or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit.

Authorized Agent's Printed Name: JAMES E. Markham REHS Date: 10-8-25Authorized Agent's Signature: James E. Markham REHS Expiration Date: 10-8-30

Owner/Legal Representative Signature: _____ Date: _____

***See attached site sketch**

Harnett County Environmental Health

SITE SKETCH

PIN _____

Permit Number EH 2509-0010

Jacob + Jermig Gardner
Applicant's Name

1
Subdivision/Section/Lot Number

James C. Markham
Authorized State Agent

10-8-25
Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

Scale = NTS

