

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION
307 W. CORNELIUS HARNETT BLVD.
LILLINGTON, NC 27546
910-893-7547 PHONE
910-893-9371 FAX

Application for Repair

EMAIL ADDRESS: john.phelps@ncparks.gov

OWNER NAME NC State Parks

PHONE 919-218-6410

PHYSICAL ADDRESS 3009 Raven Rock Rd, Lillington NC

MAILING ADDRESS (IF DIFFERENT THAN PHYSICAL) 1615 Mail Service Center Rd, Raleigh NC 27699

IF RENTING, LEASING, ETC., LIST PROPERTY OWNER NAME _____

SUBDIVISION NAME	LOT #/TRACT #	STATE RD/HWY	SIZE OF LOT/TRACT
Type of Dwelling: ☐ Modular ☐ Mobile Home ☐ Stick built ☐ Other <u>State Park, Raven Rock Restroom</u>			
Number of bedrooms <u>0</u> ☐ Basement			
Garage: Yes ☐ No ☒	Dishwasher: Yes ☐ No ☒		Garbage Disposal: Yes ☐ No ☒
Water Supply: ☐ Private Well ☐ Community System ☒ County			

Directions from Lillington to your site: Hwy 421 to Raven Rock Rd,
Go into Park to Main parking lot, the Dayuse Restroom building is by the
Field parking lot in the woods, We are wanting to replace the current septic tank
and leach field area

In order for Environmental Health to help you with your repair, you will need to comply by completing the following:

1. A "surveyed and recorded map" and "deed to your property" must be attached to this application. Please inform us of any wells on the property by showing on your survey map.
2. The outlet end of the tank and the distribution box will need to be uncovered and property lines flagged. After the tank is uncovered, property lines flagged, underground utilities marked, and the orange sign has been placed, you will need to call us at 910-893-7547 to confirm that your site is ready for evaluation.

Your system must be repaired within 30 days of issuance of the Improvement Permit or the time set within receipt of a violation letter. (Whichever is applicable.)

By signing below, I certify that all of the above information is correct to the best of my knowledge. False information will result in the denial of the permit. The permit is subject to revocation if the site plan, intended use, or ownership changes.

Owner Signature 

9-25-25

Date

HOMEOWNER INTERVIEW FORM

It is important that you answer the following questions for our inspectors. Please do not leave any blanks if possible, and answer all questions to the best of your ability. Thank You.

Have you received a violation letter for a failing system from our office? ☐ YES ☒ NO

Also, within the last 5 years have you completed an application for repair for this site? ☐ YES ☒ NO

Year home was built (or year of septic tank installation) 1986

Installer of system State Park System

Septic Tank Pumper —

Designer of System State Parks

1. Number of people who live in house? # adults # children # total
2. What is your average estimated daily water usage? 200 gallons/month or day county water. If HCPU please give the name the bill is listed in NC State Parks
3. If you have a garbage disposal, how often is it used? ☐ daily ☐ weekly ☐ monthly
4. When was the septic tank last pumped? How often do you have it pumped?
5. If you have a dishwasher, how often do you use it? ☐ daily ☐ every other day ☐ weekly
6. If you have a washing machine, how often do you use it? ☐ daily ☐ every other day ☐ weekly ☐ monthly
7. Do you have a water softener or treatment system? ☐ YES ☐ NO Where does it drain?
8. Do you use an "in tank" toilet bowl sanitizer? ☐ YES ☒ NO
9. Are you or any member in your household using long term prescription drugs, antibiotics or chemotherapy? ☐ YES ☒ NO If yes please list
10. Do you put household cleaning chemicals down the drain? ☐ YES ☒ NO If so, what kind?
11. Have you put any chemicals (paints, thinners, etc.) down the drain? ☐ YES ☒ NO
12. Have you installed any water fixtures since your system has been installed? ☐ YES ☒ NO If yes, please list any additions including any spas, whirlpool, sinks, lavatories, bath/showers, toilets
13. Do you have an underground lawn watering system? ☐ YES ☒ NO
14. Has any work been done to your structure since the initial move into your home such as, a roof, gutter drains, basement foundation drains, landscaping, etc? If yes, please list
15. Are there any underground utilities on your lot? Please check all that apply:
☒ Power ☐ Phone ☐ Cable ☐ Gas ☒ Water
16. Describe what is happening when you are having problems with your septic system, and when was this first noticed?
slow drainage, sewer backup, leach field is root bound, wanting to replace complete system outside of building
17. Do you notice the problem as being patterned or linked to a specific event (i.e., wash clothes, heavy rains, and household guests?) ☒ YES ☐ NO If Yes, please list Heavy visitor Usage



5330021

STATE OF NORTH CAROLINA
COUNTY OF HARNETT

D E E D

THIS DEED, made this the 8th day of October, 1970, by
LIZZIE MCKAY, unmarried, of Harnett County, State of North
Carolina, party of the first part, to the STATE OF NORTH
CAROLINA, party of the second part:

W I T N E S S E T H:

That the said party of the first part, in consideration
of Six Thousand One Hundred Four (\$6,104.00) Dollars and other
valuable considerations to her paid by the said party of the
second part, the receipt of which is hereby acknowledged, but
subject to the life estate herein reserved, has bargained and
sold and by these presents does bargain, sell, and convey unto
the said party of the second part, its successors and assigns,
a tract or parcel of land in the County of Harnett, and State
of North Carolina, in Upper Little River Township, and being
more fully described as follows:


TRACT TWO: BEGINNING at a railroad spike in the center
of Rural Paved Road No. 1250, said spike being located
North 3 deg. 10 min. West, a distance of 880.5 feet
from the intersection of the center line of Secondary
Road No. 1250 with the center line of Secondary Road
No. 1262, and runs thence North 45 deg. 15 min. West,
a distance of 249.4 feet to an iron pipe; thence North
60 deg. 45 min. West, a distance of 679.6 feet to an
iron pipe; thence North 23 deg. 10 min. East, a dis-
tance of 163.2 feet to an iron pipe; thence North 32
deg. 20 min. East, a distance of 233.0 feet to an iron
pipe; thence North 22 deg. 00 min. East, a distance of
567.0 feet to an iron pipe; thence South 72 deg. 55 min.
East, a distance of 460.0 feet to an iron pipe; thence
North 06 deg. 10 min. East, a distance of 465.0 feet
to an iron pipe; thence South 49 deg. 45 min. East, a
distance of 517.5 feet to a railroad spike in the center
of a farm road; thence along the various courses and
distances of said farm road South 22 deg. 30 min. West,
a distance of 131.0 feet to an iron pipe; thence South
29 deg. 15 min. West, a distance of 568.0 feet to an
iron stake; thence South 34 deg. 00 min. West, a
distance of 269.0 feet to a railroad spike; thence
South 12 deg. 35 min. West, a distance of 243.4 feet
to a railroad spike; thence South 02 deg. 30 min. East,

LAW OFFICES OF
BRYAN, JONES
AND JOHNSON
ATTORNEYS AT LAW
DUNN, N. C.
AND
LILLINGTON, N. C.

TRANSFER RECORDED IN THE
OFFICE OF HARNETT COUNTY
TAX SUPERVISOR

ON Oct 14 1970
TAX SUPERVISOR

BY J. Allen



a distance of 297.0 feet to the point of beginning, and containing 21.800 acres, more or less, and formerly being known as McKay's fields, according to survey and plat of G. W. Russum, R.L.S., dated May, 1970.

However, this conveyance is made subject to a life estate in the aforescribed lands, which is hereby expressly excepted and reserved by the party of the first part for and during her natural life.

This deed is also subject to an easement of Carolina Power and Light Company dated October 3, 1955 and recorded in Book 362 at Page 141 of the Harnett County Registry.

The above described property is a portion of the property which was devised to Lizzie McKay by the Will of S. Prentice McKay, said Will being recorded in Wills 3935, Office of the Clerk of Superior Court of Harnett County, North Carolina. See also deed from Heirs of Margaret Billy McKay to Sidney Prentice McKay recorded in Book 271, Page 594 of the Harnett County Registry on January 29, 1940. See also deed from S. Prentice McKay to Margaret Billy McKay recorded in the Harnett County Registry in Book J-2, Page 470 on 14 September, 1895.

TO HAVE AND TO HOLD the aforesaid tract or parcel of land and all privileges and appurtenances thereto belonging to the said party of the second part and its successors and assigns, forever, but subject always to the life estate herein reserved by the said party of the first part.

And the said party of the first part covenants that she is seized of said premises in fee and has the right to convey the same in fee simple; and that the same are free from encumbrances; and that she will warrant and defend the said title to the same against the claims of all persons whatsoever.

IN TESTIMONY WHEREOF, the said party of the first part has hereunto set her hand and seal the day and year first above written.

Lizzie McKay (SEAL)
Lizzie McKay


LAW OFFICES OF
BRYAN, JONES
AND JOHNSON
ATTORNEYS AT LAW
DUNN, N. C.
AND
LILLINGTON, N. C.

NORTH CAROLINA
HARNETT COUNTY

I, Raye Horton, a Notary Public of said County and State, do hereby certify that Lizzie McKay, unmarried, personally appeared before me this day and acknowledged the due execution of the annexed Deed of Conveyance for the purposes therein expressed.

WITNESS my hand and notarial seal, this 14 day of October, 1970.

Raye Horton
Notary Public



My Commission Expires:

11-10-74

NORTH CAROLINA - HARNETT COUNTY

The foregoing certificate of Raye Horton
Notary Public of Harnett County, North Carolina,
is adjudged to be correct.

Let the said deed and certificate be registered. Witness my hand this the 14 day of October, 1970.

Flora J. Mullen, asst
Register of Deeds

Filed for registration on the 14 day of October, 1970, at 2:55 clock P.M., and duly recorded in the office of the Register of Deeds of Harnett County, N.C., in Book 533, Page 21.

By Flora J. Mullen, asst
Register of Deeds

Fee \$ _____ paid

07-5-19085
07-5-19086
HTE# 07-5-19084

Harnett County Department of Public Health

21237

PERMIT # 24533

Operation Permit

☒ New Installation ☒ Septic Tank ☐ Repair ☒ Nitrification Line ☐ Expansion

PROPERTY LOCATION: RAVEN ROCK RD

Name: (owner) CLH DESIGN PA (RAVEN ROCK SP) SUBDIVISION _____ LOT # _____

System Installer: GERALD TEMPLE Registration # _____

Basement with plumbing: ☐ Garage ☐ Number of Bedrooms 7200SF VISTAR CENTER (5700sqd)


Type of Water Supply: ☐ Community ☒ Public ☐ Well Distance from well 100 feet

System Type: III b Types V and VI Systems expire in 5 years.

(In accordance with Table V a)

Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



PERMIT CONDITIONS:

I. Performance: System shall perform in accordance with Rule .1961.

II. Monitoring: As required by Rule .1961.

III. Maintenance: As required by Rule .1961. Other: _____

Subsurface system operator required? Yes ☐ No ☒

If yes, see attached sheet for additional operation conditions, maintenance and reporting.

IV. Operation: _____

V. Other: _____

EQUAL REPAIR AREA LOCATED BEYOND INITIAL DRAINFIELD. CONTROL PANEL LOCATED ON BUILDING

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: ☐ Conventional ☒ Other PUMP TO CHAMBER Septic Tank: 1500 gallons Pump Tank: 1250 gallons


Subsurface No. of exact length width of drainage field ditches 6 of each ditch 68 feet ditches 3 feet depth of ditches 12-18 inches

French Drain Required: _____ Linear feet

Authorized State Agent _____


REHS

Date 1/8/10



98061-5-40





98061-5-L0

