

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows:

Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Curran Builders Inc ☒ New Installation ☒ Septic TankProperty Location: SR 1440 ☒ Repairs ☒ Nitrification LineKennis Creek lot # 10Number of Bedrooms Proposed: 2 ☒ Dish Washer ☐ Garbage DisposalLot Size: 3/4 acre Water Supply: ☐ Well ☒ City ☐ CommunityDistance From Well? ☐Above information certified by: Application

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Kind of Material for Tank:

☒ Concrete☐ Other

Size of Tank:

Capacity 900 GallonsSubsurface No. of 2 Exact Length 100 Width of 3 Depth of 20 Inches
Drainage Field Ditches of each Ditch Ft. Ditches Ft. Ditches

Any Change in the layout of this system without prior approval of the issuing authority will result in this permit being void.

Date: 03/20/91Signed: Charles H. Wood Jr.

(SANITARIAN)

Void After 5 Years

This permit is subject to revocation if site plans or intended use change.

* Maintain 10' from property line.

* Don't run lines over ridge.

