



March 23, 2021

Department of Environmental Health

www.harnett.org

Jose Torres
324 Grand Hill Place
Holly Springs, NC 27540

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

W.S. Architects
3305-109 Durham Dr.
Raleigh, NC 27501

ph: 910-893-7547
fax: 910-893-9371

Mi Cancun
115 South Raleigh St.
Angier, NC 27501

Dear Mr. Torres,

The application, plans and specifications for the above referenced facility were reviewed and cannot be approved at this time. Enclosed you will find the application. Provide information for the highlighted items and resubmit the completed application to our office.

The proposed plan increases seating/dining space significantly without proportionately increasing the kitchen size. The existing facility did not adequately support the dining area and menu. The facility had permit conditions limiting food processes due to limited refrigeration, dishwashing area and storage. While there are positive changes in respect to the proposed kitchen plan, changes are needed in order to adequately address dry storage, dishwashing, air-drying and utensil storage.

In addition, the extensive menu and processes require additional prep space, such as prep tables. The size of the walk-in cooler/freezer combo must be larger to accommodate the refrigerated produce, raw meat species, thawing, prepared food and multiple types of salsas. The bar area shall provide a three compartment sink for the washing of glassware. No soiled raceway is identified. Specify where soiled utensils are staged in kitchen. Specify where bulk hot foods are held prior to placing in hot wells. Per a conversation with the Fire Marshal, the hallway cannot be used for storage. Specify on plans where large chip containers and bulk dry goods, such as large bags of beans, rice, etc. are stored. Specify if liquor is served and storage location. Provide spec sheets for wall mount shelving in bar and cabinetry. Please resubmit revised plans to Harnett County Central Permitting. The completed application shall be resubmitted to Harnett County Environmental Health.

The review of this facility was made using "2009 NC Food Code" and "15A NCAC 18A .2600 Rules Governing the Food Protection and Sanitation of Food Establishments".

If you have questions or concerns, please call me at (910) 893-7547.

Sincerely,


Jamie Turlington, REHS

Harnett County Environmental Health
(910) 893-7547