



May 14, 2021

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Jose Torres
324 Grand Hill Pl.
Holly Springs, NC 27540

ph: 910-893-7547
fax: 910-893-9371

Ginger Summer
W.S. Architects
3305-109 Durham Dr.
Raleigh, NC 27603

RE: Mi Cancun

Dear Mr. Torres and Ms. Summer,

A plan review was received by this office concerning the construction of the above referenced facility. The plans and specifications submitted are approved with the following comments:

Changes to equipment specifications and plan are approved as per conversations with Ginger through email and by phone. Approved changes are moving the dirty staging rack closer to the dump sink, a solid top version of the dirty glassware staging rack, bar ice bin shall have a lid, wire shelf to replace speed rack, two door worktop refrigerator to replace condiment cooler in prep room and provide a self-closure on sliding window in bar.

Food equipment shall comply with 4-205.10 Food Equipment, Certification and Classification of the North Carolina Food Code Manual.

Any changes deviating from this approval shall be approved by Environmental Health.

Any item not shown on the plans or referenced above will be required to comply with 15A NCAC 18A .2600, "**Rules Governing the Food Protection and Sanitation of Food Service Establishments**" and "**The North Carolina Food Code Manual**". This review does not cover any other aspects of construction regulated by other jurisdictions.

If you require further assistance, please call 910-893-7547.

Sincerely,

Jamie Turlington, REHS
Environmental Health Section
Harnett County Health Dept.