

June 7, 2021

Ralph Babb / Robert Stapleton
CDKS, Inc.
9229 Carley Circle
Garner, NC 27529

RE: Napper Tandy's

Dear Sirs,

A plan review was received by this office concerning the construction of the above referenced facility. The plans and specifications are approved with the following comments:

-Due to open dining concept utilizing large garage door style openings on the exterior wall, the doors to the main kitchen area shall comply with 6-202.15 Outer Openings, Protected of the North Carolina Food Code Manual.

Any item not shown on the plans or referenced above will be required to comply with 15A NCAC 18A .2600, "**Rules Governing the Food Protection and Sanitation of Food Service Establishments**" and "**The North Carolina Food Code Manual**". This review does not cover any other aspects of construction regulated by other jurisdictions.

If you require further assistance, please call 910-893-7547.

Sincerely,



Cindy Pierce, REHS
Environmental Health Section
Harnett County Health Department