

May 13, 2022

Brandon King  
152 N. Dam Street  
Angier, NC 27501

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

ph: 910-893-7547

fax: 910-893-9371

Re: Kicking Camel Grill Plan Review  
174 N. McKinley St.  
Coats, NC 27521

Dear Mr. King,

This letter acknowledges the review for the above referenced establishment. The plan, received 5-6, and specifications are approved with the following comments:

- 1- All food equipment must comply with subpart 4-205 of the North Carolina Food Code and installed as specified in Sections 4-402.11 and 4-202.12.
- 2- Lighting must comply with Sections 6-202.11 and 6-303.11 of the North Carolina Food Code.
- 3- Handwash sinks shall have splashguards.
- 4- Floors, walls, and ceilings finishes shall comply with Sections 6-101.11 and 6-201.11 of the North Carolina Food Code.

The establishment must comply with the requirements of the North Carolina Food Code and 15A NCAC 18A .2600, "Rules Governing the Food Protection and Sanitation of Food Establishments". This review does not cover any aspects of construction regulated by other jurisdictions.

Any changes to the approved plans must be reviewed by our office.

Sincerely,



Jamie Turlington, REHS  
Harnett County Health Dept.  
Harnett County Environmental Health