N.C. DEPARTMENT OF HEALTH AND HUMAN SERVICES DIVISION OF PUBLIC HEALTH ENVIRONMENTAL HEALTH SECTION

Notice of Permit Denial

DATE:

STATE: NC ZIP CODE: 2752 TIME 10 am
Dear Owner or Operator:
In response to your application, an evaluation or review has been conducted in accordance with the laws and rules governing:
food and lodging establishments in North Carolina General Statutes 130A-247 through 130A-250 and related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule .2600 and related rules. () public swimming pools in North Carolina General Statutes 130A-280 through 282 and related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule .3200 and related rules.
As a result of this evaluation or review, the Department has determined that the establishment is in noncompliance of Title 15A, Subchapter 18A, of the North Carolina Administrative Code, due to the following noncompliant items:
Sel lettere dated 6/24/22 with first of Noncompliant items at walkfurbugh on 6/23/22
Because of the above noncompliant items, the law prohibits operation of an establishment without a permit. Operation of an establishment without a permit may lead to civil action to require you to cease operation, or criminal charges in accordance with G.S. 130A-25.
You have a right to a formal appeal of this decision. To pursue a formal appeal, you must file a petition for a contested case hearing with the Office of Administrative Hearings, 6714 Mail Service Center, Raleigh, NC 27699-6700. To get a copy of a petition form, you may write the Office of Administrative Hearings, visit the website, or call the office at (919) 431-3000. The petition for a contested case hearing must be filed in accordance with the provisions of North Carolina General Statutes 130A-24 and 150B-23 and all other applicable provisions of Chapter 150B.
PLEASE NOTE: If you wish to pursue a formal appeal, you must file the petition form with the Office of Administrative Hearings WITHIN 30 DAYS OF THE DATE OF THIS LETTER. Meeting the 30-day deadline is critical to your right to a formal appeal. Do not wait for the outcome of any informal review or appeal if you wish to file a formal appeal.
If you file a petition for a contested case hearing with the Office of Administrative Hearings, you are required by Law (N.C. General Statutes 150B-23) to serve a copy of your petition on the state agency that is a party to the action. The state agency party in this case is the North Carolina Department of Health and Human Services. You must send the copy to: Office of General Counsel, N.C. Department of Health and Human Services, 2001 Mail Service Center, Raleigh, NC 27699-2001. Do NOT send the copy of your petition to your local health department. Sending a copy of your petition to the local health department will NOT satisfy the legal requirements in N.C. General Statute 150B-23 that you serve a copy on the state agency that is a party to this action.
We will the laid health department if you need any additional information or aggistance
You may call or write the local health department if you need any additional information or assistance. Amue Array to Letter Signature of Environmental Flouth Specialist
* call with questions * call when items are complete to Schedule inspection for primit





www.harnett.org

June 24, 2022

Kicking Camel 174 N. McKinley St. Coats, NC 27521 Harnett County Government Complex 307 W. Cornelius Harnett Boulevard Lillington, NC 27546

ph: 910-893-7547

fax: 910-893-9371

Re: Kicking Camel Permit Denial on 6-23-22

Dear Mr. King,

A walk through of the Kicking Camel Grill was completed on 6-23-22 per your request. Please see Notice of Permit Denial Form. This serves as the list as noted on the Form.

A permit was not issued due to the following:

- 1- Equipment was not in place and operational. Equipment not in place per site plan.
- 2- Floor was not smooth and sealed. Flooring shall be smooth, no holes or crevices and sealed.
- 3- Coving and trims missing and or not present along wall and floor junctures.
- 4- Gaps present along bar wall shelving and wall. Ledge present along bar wall base trim.
- 5- Gaps present inside liquor storage cabinet.
- 6- Provide flanges to close up openings around pipes entering wall.
- 7- Seal wood on the underside of bar top.
- 8- Treat facility for roaches and provide a contract with a pest control company.
- 9- Mold on walk in cooler walls. Equipment dirty. Clean all equipment, interior and exterior surfaces and cooler walls.
- 10- Residue present on floors and walls. Floors, walls and ceilings need cleaning throughout.
- 11- Gap at back door. Back door must self-close completely.
- 12- Dining room storage cabinet needs painting. Gaps present in cabinet along junctures.

- 13- No cold water at handsink.
- 14- Rusty shelving in walk in freezer.
- 15- Food processor must be NSF/ANSI approved. Hot wells placed as per site plan. Discussed moving hot well to prep table due to breading on work top freezer.
- 16- Gaskets torn or not in good repair on reach ins. Invoice for gaskets provided on 6-24.

Please call if you have questions regarding any of these items and to schedule walk through when items are complete.

Sincerely,

James Furlington, RECHL

Harnett County

Harnett County Environmental Health