

August 30, 2022

Colleen Roby
Meda Williams
27-107 Annette Dr.
Benson, NC 27504

RE: Simple Twist

To Whom It May Concern,

A plan review was received by this office concerning the construction of the above referenced facilities. The plans and specifications are not approved. Plan review cannot continue until further information is received.

- Equipment specification sheets were not included for each piece of equipment. Specification sheets shall include make, model and dimensional sizes of the equipment. Include detailed spec sheets for dish washing equipment (spec sheets for dish machines, prewash sink, raceways, 3 comp etc.), handsinks, tables etc.
- Each equipment specification sheet shall be tied to its location on floor plan and represented on floor plan accurately with respect to size.
- Menu items were specified for hot holding (rice, mashed potatoes); no hot holding equipment was indicated on plan.
- Based on menu review, refrigeration capacity is not sufficient. Based on number of meat species, amount of raw vegetable types and planned cooling, refrigeration capacity must be increased.
- No tabletop equipment is indicated on plan. Will there be a slicer, mixer, processor, microwave etc.? If so, indicate where.
- For reference only plans do not include specifications on type of lighting.
- Plans are unclear about construction of center equipment/cook area. Are there walls, half walls or other barriers and if so, where? An interior elevation would be useful.
- Indicate placement of employee locker/beverage stations on plans.
- Indicate location of soiled linen bin on plans.
- Is the square labeled "ice" an ice machine?
- Will there be an ice bin in the bar area? Is there a bar sink in the bar area? All equipment in the bar area shall be indicated on plans.
- Indicate shelving in all locations applicable on plans including in walk-in. Specification sheets should be provided as well.

- Indicate on plans where splashguards are located at prep sink/table area.
- Is the soft drink system a bag-in-box system? If so indicate where rack will be located.
- Food process sheets are not complete. Are all deli salads such as pasta salad, pimento cheese, roasted tomatillo salsa, cilantro lime slaw etc. prepared from scratch in house?

The plan review process cannot proceed without the above information.

If you require further assistance, please call 910-893-7547.

Sincerely,

A handwritten signature in black ink that reads "C. Pierce, REHS". The signature is written in a cursive style with a large initial "C".

Cindy Pierce, REHS
Environmental Health Section
Harnett County Health Department