



Permit Reviews

Harnett County

Permit Number: EHFL2209-0003

Description: Restaurant **Expired **

Applied: 9/21/2022

Approved:

Site Address: 2116 W CUMBERLAND ST

Issued:

Finalized:

City, State Zip Code: DUNN, NC 28334

Status: VOID

Applicant: Tortillerrea and Rosticeria Don Chon

Parent Permit:

Owner: RCG-DUNN LLC

Parent Project:

Contractor: <NONE>

Details:

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: 1ST PLAN REVIEW						
9/21/2022	9/22/2022	10/5/2022	HEALTH AND SANITATION	EH Bucket	DISAPPROVED	
Notes: Disapproval letter attached						
Review Group: 2ND PLAN REVIEW						
10/4/2022	10/5/2022	10/18/2022	HEALTH AND SANITATION	EH Bucket	DISAPPROVED	
Notes: Newly provided documents do not address needed information as stated in the original disapproval letter						
Review Group: 3RD PLAN REVIEW						
10/5/2022	10/28/2022	10/19/2022	HEALTH AND SANITATION	EH Bucket	DISAPPROVED	mtg for 10/19/22 at 9 am
Notes: Facility has unapprovable equipment/ layout. Building, Fire and EH met on site 10/26 and will continue to work with the operator to find a resolution.						
2/9/2023	2/10/2023		HEALTH AND SANITATION	Cynthia Pierce	APPROVED	
Notes:						
Review Group: ALL						
10/19/2022	10/20/2022	11/2/2022	FIRE MARSHAL	Leslie Jackson	DISAPPROVED	See Notes
Notes: 1 - Need to submit a life safety plan. 2 - Need to show kitchen hood size. 3 - Need to show hood suppression system						