

January 20, 2023

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Doug Liggett
7 Crows Nest
Whispering Pines, NC 28327

ph: 910-893-7547
fax: 910-893-9371

RE: Rudino's Cameron


Dear Mr. Liggett,

A plan review was received by this office concerning the construction of the above referenced facility. The plans are not approved at this time with the following comments:

- The floor plan/equipment layout is not drawn to a recognizable scale.
- Equipment shown on the floor plan is not complete. Specification sheets were received for equipment that was not subsequently shown on floor plan. Items include but are not limited to tabletop warmers, hot holding cabinet, reach-in freezer.
- Indicate what is in the place where the interior walk-in was previously located.
- No specification sheet was received for the following pieces of equipment: three comp sink, food prep sinks, shelving, dish machine and raceways, water heaters and walk-in cooler.
- Food process sheets are incomplete and are lacking detail. There are no process sheets for some items such as dough indicating frequency and quantity. Where will large bags of flour and dough trays be stored? What is the water source for dough mixing?
- Where will empty kegs be stored? Will there be keg storage in the walk-in cooler?
- The food prep sinks appear to overlap. This is not an approved arrangement.
- Please indicate the use of the sink located in the bar area.
- The exterior walk-in does not enter directly into the kitchen area. This unit will therefore be for food delivered and received that is packaged. The walk-in will be for long term storage only and cannot be used as a working refrigeration unit.
- The application indicates ware washing sink compartments are 13.5" deep. There is concern as to whether this would allow proper washing of full size sheet pans and larger utensils such as the mixer dough bowl.
- Ceiling tiles in the restrooms are listed as being acoustic. Toilet room ceilings are required to be non-absorbent and washable.
- Floor and base coverings are listed as epoxy. The floor to wall juncture shall be coved.

Any item not shown on the plans or referenced above will be required to comply with 15A NCAC 18A .2600, **"Rules Governing the Sanitation of Food Service Establishments"** and the **2017 NC Food Code**. This review does not cover any other aspects of construction regulated by other jurisdictions.

If you require further assistance, please call 910-893-7547.

Sincerely,

Cindy Pierce, REHS
Environmental Health Section
Harnett County Health Department
strong roots • new growth