

February 10, 2023

Doug Liggett  
7 Crows Nest  
Whispering Pines, NC 28327

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

ph: 910-893-7547  
fax: 910-893-9371

RE: Rudino's Cameron

Dear Mr. Liggett,

A plan review was received by this office concerning the construction of the above referenced facility. The plans are not approved at this time with the following comments:

- The specification sheets include a chef base with countertop griddle. This item is not included on the floor plan most recently submitted. If this item is still intended to be used please indicate placement.
- Identify the L shaped apparatus in the corner of the area labeled 'prep room'.
- There appears to be a splashguard (as would be required) between the prep sinks. Please indicate material of construction and method of attachment.
- No raceways appear to be provided for dish machine. Please indicate location and placement and submit specification sheets for raceways.
- The location as shown of the large mixer is in close proximity to the rear entry door. Access to the mixer also appears to be partially blocked on both sides by the three door cooler and what comprises the L shaped apparatus. It is recommended that the mixer be relocated to allow for easier access and to preclude any potential contamination from exposure to rear entry.
- Any items added or relocated should be noted on an updated floor plan.

Any item not shown on the plans or referenced above will be required to comply with 15A NCAC 18A .2600, **"Rules Governing the Sanitation of Food Service Establishments"** and the **2017 NC Food Code**. This review does not cover any other aspects of construction regulated by other jurisdictions.

If you require further assistance, please call 910-893-7547.

Sincerely,



Cindy Pierce, REHS  
Environmental Health Section  
Harnett County Health Department