

October 24, 2023

Michael and Beth Anderson
613 Far Post Dr.
Fuquay Varina, NC 27526

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

RE: Wingin' It

Dear Mr. and Mrs. Anderson,


A plan review was received by this office concerning the construction of the above referenced facility. The plans are approved at this time with the following comments:

- The prep sink currently located in the dish room will be relocated adjacent to blast chiller.
- The chemical dispensing system located on the wall at the double doors will be removed.
- The handsink will be moved to the left where the chemical dispensing system was to allow for installation of a larger chicken prep sink.
- The three door refrigerator will be relocated to the wall across from the chicken prep sink.
- Adequate shelving and staging shall be provided in dish/dry storage room.
- A can wash will be provided on the exterior of the building. Facility shall be curbed and drain into the sewer system.

Any item not shown on the plans or referenced above will be required to comply with 15A NCAC 18A .2600, **"Rules Governing the Sanitation of Food Service Establishments"** and the **2017 NC Food Code**. This review does not cover any other aspects of construction regulated by other jurisdictions.

If you require further assistance, please call 910-893-7547.

Sincerely,



Cindy Pierce, REHS
Environmental Health Section
Harnett County Health Department