



NC DEPARTMENT OF  
**HEALTH AND  
HUMAN SERVICES**

**ROY COOPER** • Governor

**KODY H. KINSLEY** • Secretary

**MARK T. BENTON** • Chief Secretary for Public Health

**SUSAN KANSAGRA** • Assistant Secretary for Public Health

Division of Public Health

October 17th, 2023

Jennifer Bardeschewski  
Commercial Permit and Expediting, LLC  
601 Wimbleton Drive  
Raleigh, NC 27609

RE: McDonald's #32-0051  
1726 W. Cumberland St.  
Dunn, NC 28334

Dear Ms. Bardeschewski:

The letter acknowledges review of the remodel plan for the above reference establishment. The plans received on 07/25/2023, application and drawings, specifications, including e-mail correspondence and are approved with the following comments:

1. Food will be handled as indicated on the provided plan review application.
2. The scope of work for remodel includes a front counter modification to accommodate specialty beverages and dessert production. A pickup shelf will also be added for online orders. This modification will also entail repairing/remodeling existing walls and finishes as required. The addition of equipment items (listed in the included scope of work) are approved to include the following: ice machines & dispensers, beverage system, espresso brewer, juice and sweetener dispensers, a reach in refrigerator and landing zones.
3. In addition, a new hand sink will be installed at this pick-up counter area, to supply convenient and accessible hand washing to all food preparation, and food dispensing areas and to meet NC Food Code requirements.
4. All food equipment (including water heaters) must comply with Section 4-205.10 of the North Carolina Food Code and be installed as specified in Sections 4-402.11 and 4-202.12. All existing equipment to be relocated shall be maintained in good repair and comply with Parts 4-1 and 4-2 of the NC Food Code. If FUELS- food, cleaned utensils and equipment, linens, and single-service/single use items (disposables) are not protected from contamination by removal,

**NC DEPARTMENT OF HEALTH AND HUMAN SERVICES • DIVISION OF PUBLIC HEALTH**

LOCATION: 5605 Six Forks Road, Building 3, Raleigh, NC 27609  
MAILING ADDRESS: 1931 Mail Service Center, Raleigh, NC 27699-1931  
www.ncdhhs.gov • TEL: 919-707-5000 • FAX: 919-870-4829

AN EQUAL OPPORTUNITY / AFFIRMATIVE ACTION EMPLOYER

protective coverings or barriers must be erected to protect interior kitchen areas or other approved means will need to be provided during remodeling; as noted on the B1.0 Floor Plan sheet.

5. Damaged finishes incurred during this remodel will be replaced to their original, undamaged condition and be made in good repair. New finishes must be smooth, durable, and easily cleanable for areas where food establishment operations occur. In addition, the wall and floor junctions in all food service areas, walk-in coolers/ freezers and toilet room areas must be coved.
6. The existing plumbing system is approved for continuous use if it meets Section 5-1, 5-2, and Parts 6-3, 6-4. And 6-5 of the Food Code. In addition, a new mop sink and associated plumbing should be installed; as shown in the Plumbing Fixture Schedule on the P4.0 General Notes plan sheet.
7. Lighting in the food establishment and all supporting facilities must comply with Sections 6-202.11 and 6-303.11 of the Code.
8. All windows, including new drive-thru windows, will need to have protection provided by providing a self-closing door and insect protection. This is approved and properly documented on page 7 of the completed plan review application.
9. Documentation verifying dumpster cleaning meets Food Code requirements and continued off-site cleaning of the dumpster may be required by Harnett County Environmental Health.
10. This review does not cover any aspects of construction regulated by other jurisdictions.

The establishment must comply with the requirements of the North Carolina Food Code and 15A NCAC 18A .2600 "Rules Governing the Food protection and sanitation of Food Establishments." These documents are available on our web page at: [ehs.ncpublichealth.com/faf/food/planreview/index.htm](https://ehs.ncpublichealth.com/faf/food/planreview/index.htm).

Any changes made to the approved plans must be reviewed by our office. If I can be of further assistance, please contact me at [sarah.morgan@dhhs.nc.gov](mailto:sarah.morgan@dhhs.nc.gov).

Sincerely,

*Sarah Morgan*

Sarah Morgan, EHS  
Food Service Plan Review, Environmental Health Specialist  
Plan Review Unit  
Division of Public Health, Food Protection Branch  
North Carolina Department of Health and Human Services

cc. Harnett County Environmental Health