

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

April 29, 2024

Jennifer Bardeschewski  
Commercial Permit Expediting, LLC  
601 Wimbelton Dr.  
Raleigh, NC 27609

ph: 910-893-7550  
fax: 910-893-9429

Re: Caitlin Crossing

Dear Ms. Bardeschewski:

This department has reviewed the plan you submitted for the Caitlin Crossing swimming pool to be constructed on Matthews Rd, Lillington. This plan review was conducted in accordance with the current North Carolina Rules Governing Public Swimming Pools (15A NCAC 18A .2500).

The plans have been approved contingent upon items that are in contradiction between sets of plans such as type of fencing or whether doors to pump and chemical rooms have vents or not are in final compliance with the .2500 rules. The restroom floors shall be slip resistant.

This approval is valid for one year from the date of this letter and applies only to the pool and related appurtenances. If construction is not initiated within one year from the date of approval, the approval shall expire and plans must be re-submitted.

Under the current provisions of the North Carolina Rules Governing Public Swimming Pools (15A NCAC 18A .2500), the pool shall be constructed by swimming pool contractors licensed by the North Carolina Licensing Board for General Contractors.

Prior to issuance of the operation permit, the owner shall submit to this department a statement signed by a registered design professional stating that construction is complete and in accordance with approved plans and specifications and approved modifications. Observation of construction and a final inspection for design compliance by the certifying registered design professional or his representative are required for this statement.

Please notify me prior to placement of concrete so an inspection can be made of the pool piping. Upon completion of construction, the owner must apply to this department for an operation permit. A final inspection must be made and an operation permit must be issued before bathers can use the pool.

If you have any questions regarding this matter or if I can provide any additional assistance, please call me at 910-893-7547

Sincerely,

  
Cindy Pierce, REHS  
Environmental Health Specialist