

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

July 29, 2024

ph: 910-893-7550

fax: 910-893-9429

Radical Loth
19700 Mariner Ave.
Torrance, CA 90503

RE: AFC Sushi @ Campbell University

A plan review application was received by this office concerning the construction of the above referenced facility. The application is approved at this time with the following comments:

- The number of sink compartments for manual dishwashing facilities was marked as 1. It is understood from previous knowledge of the facility that there is an existing 3 compartment sink. The 3 compartment sink shall be utilized for the proper washing, rinsing and sanitizing of utensils.
- A consumer advisory shall be provided at point of ordering. Provided menu did not include a consumer advisory.

Any item not shown on the plans or referenced above will be required to comply with 15A NCAC 18A .2600, **“Rules Governing the Sanitation of Food Service Establishments” and the 2017 NC Food Code.** This review does not cover any other aspects of construction regulated by other jurisdictions.

If you require further assistance, please call 910-893-7547.

Sincerely,



Cindy Pierce, REHS
Environmental Health Section
Harnett County Health Department