

**Pool Drain Safety Compliance Data**  
**PERMIT CANNOT BE ISSUED IF FORM IS INCOMPLETE**

A separate form is required for each pump including circulation, jet or feature.

Name of Pool Camden Place - Circulation Pump ID# \_\_\_\_\_

**1. Pump Flow**

Pump Manufacturer Hayward Model # Tristar VS 950 Horsepower 2.7

Maximum Pump Flow at highest speed FROM PUMP CURVE: 195 gpm. Pump use:  Circulation / jet / feature (circle one)

Has pump been serviced (disconnected from power for any reason) or changed out in last 12 months? YES /  NO

Flow meter manufacturer Flowvis Flow meter reading TBD GPM

**2. Drain Sump Measurements** Is drain cover sumpless? YES /  NO

Sump manufacturer and model Aquastar WAV9WR101SSB OR: Field built sump (circle if yes)

Diameter of pipe entering sump 4" inches. Pipe enters through BOTTOM /  SIDE of sump (Must circle one)

Distance between highest point of outlet pipe and top edge of sump 5.6" inches. Sump dimensions 9" x 9"

**3. Drain Cover Data – MUST BE INSTALLED PER MANUFACTURER'S INSTRUCTIONS- Attach Instructions to form.**

Number of main drains on each pump 2 Distance between main drains (on centers) 8 feet 0 inches

Cover/grate manufacturer Aquastar, model WAV9WR, VGBA approval 2008 /  2017 (circle one)

Flow rating from instructions: 224 gpm Cover(s) located on pool: Floor / wall (circle one)

Date installed TBD Lifespan 5 years EXPIRATION DATE TBD

**4. Equalizer Covers**

Number of operable skimmer equalizers 0 Have the equalizers been permanently disabled? YES / NO

Equalizer fitting Manufacturer \_\_\_\_\_, Model \_\_\_\_\_, Lifespan \_\_\_\_\_

Bulkhead adaptor Manufacturer \_\_\_\_\_, Model \_\_\_\_\_, Date Installed \_\_\_\_\_

Diameter of equalizer pipe \_\_\_\_\_ Cover is located on (circle where mounted): Floor / wall

Equalizer fitting maximum flow rating \_\_\_\_\_ gpm.

Date equalizer cover/grates installed \_\_\_\_\_ EXPIRATION DATE: \_\_\_\_\_

**5. Safety Vacuum Release System (SVRS) – Safety Vacuum Release System manufacturer/model# - N/A**

You will be required to demonstrate effectiveness during permitting inspection. Date last tested \_\_\_\_\_

**6. Vacuum Line** Choose One

No vacuum line in pool OR \_\_\_\_\_ Protective cover on vacuum lines installed before May 1, 2010, OR  
 Self-closing, self-latching cover designed to be opened with a tool on vacuum lines installed after May 1, 2010

Full name of person providing this information Philip Kennel Phone number: 919-859-7003 x 103

Signature  Date 12/11/24