

William Parker
554 McNeill Mill Rd.
Broadway, NC 27505
Re: Parker's Pizza

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546
ph: 910-893-7550
fax: 910-893-9429

Dear Mr. Parker,

The plans for this facility have been reviewed and are approved with the following conditions:

1- Equipment must meet NC Food Code 4-205.10 Food Equipment, Certification and Classification. Food equipment shall be used in accordance with the manufacturer's intended use and certified or classified for sanitation by an American National Standards Institute (ANSI)-accredited certification program. All equipment must meet 4-205.10.

2-The water heater submitted is approved per the hot water calculations. If the water heating systems do not meet the required hot water demand, the hot water heating system will require modification and/or replacement to meet NC Food Code requirements. An additional hot water heater will be installed to service some of the water using fixtures.

3-The floors, walls and ceilings shall comply with NC Food Code 6-101.11 and 6-201.11 Please note that all finishes shall be durable and easily cleanable for areas where food operations occur. Floor and wall junctures in all foodservice areas, walk in cooler and in toilet rooms must be coved.

4-Lighting in food service areas must comply with NC Food Code Sections 6-202.11 Light Bulbs, Protective Shielding and 6-303.11 Intensity.

5-The one compartment prep sink will be designated for vegetable preparation only. All meats must arrive ready to cook or serve.

6-The dumpster shall be stored on a nonabsorbent surface, and must be a concrete dumpster pad shall be provided or ensure the dumpster is stored on a surface of nonabsorbent material, such as concrete or asphalt.

Any changes to the plans, equipment, and food processes must be submitted to Central Permitting and approved by Harnett County Environmental Health.

A construction visit by our Department is required prior to the issuance of the final permit. Request a construction visit by calling Donna Johnson with Central Permitting at (910) 814-6431.

The establishment must comply with the requirements of the North Carolina Food Code and 15A NCAC 18A .2600, "Rules Governing the Food Protection and Sanitation of Food Establishments."

This review does not cover any aspects of construction regulated by other jurisdictions.

Please contact me with any questions.

Sincerely,

A handwritten signature in black ink that reads "Jamie Turlington, REHS". The signature is fluid and cursive, with the initials "REHS" written in a slightly different, more blocky style than the first name.

Jamie Turlington, REHS
Harnett County Environmental Health
Harnett County Health Dept.
(910) 893-7547