

Items noted on construction walk-thru include
but are not limited to:

N.C. DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

Comment Addendum

COUNTY: Harnett
NAME: Matthews Landing ID: _____
STREET: _____
CITY: _____ DATE: 8/25/25
STATE: _____ ZIP CODE: _____ TIME: _____

COMMENTS

- Autofill line not present
- Vac line @ 21" w/out deck/bullnose - should be $\leq 18"$ total depth
- 2" line present on return line b/t T's - should be 3" (near main fbb)
- return line not connected to inlet @ sun shelf
- 2" line present between skimmers - should be 3" @ skid/steps
- overflow line plumbed to return pipe - overflow stubout too low - overflow should be plumbed to channel drains or to daylight - stubout should be on tile line above operational H₂O level
- move or adjust electrical conduits for light junction boxes outside the fence so that no foothold is created.
- Find bubbler lines & connect them properly

Signature of Environmental Health Specialist

Signature of Recipient

Instructions:

Purpose: This form is developed to be used for making explanatory comments about violations observed during inspections and/or notices of permit actions during inspections of restaurants, foodstands, commissaries, hotels, bed and breakfast homes and inns, summer camps, meat markets, institutions, residential care facilities, public swimming pools, tattoo establishments and other establishments inspected by Environmental Health Specialists under rules adopted by the Commission for Health Services. Preparation: local Environmental Health Specialists shall complete form DENR 4008 when necessary during inspections and/or notices of permit actions. The original and two copies will be distributed with the form about which they provide comments. Disposition: This form may be destroyed in accordance with Standard &, Inspection Records of the Records Disposition Schedule published in the N.C. Division of Archives and History.

Additional Forms may be ordered from: Division Of Environmental Health 1630 Mail Service Center, Raleigh, NC 27699-1630 (Courier 52-01-00)

Environmental Health Services Section (Review 10/06)

DENR 4008 - Revised 10/04

Environmental Health Services Section (Review 10/07)

Cindy Pierce 910-843-7592
910-984-2000