

N.C. DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

Comment Addendum

COUNTY: Harnett
NAME: Matthews Landig ID: _____
STREET: _____
CITY: _____ DATE: 9/3/25
STATE: _____ ZIP CODE: _____ TIME: _____

COMMENTS

- 2nd Lang Plumb - Auto-fill connected to Return Stubout -
No Stubout provided for auto-fill
- Section of piping is 3", plans spec 2" (pipe
was marked during inspection)
- Excessive bends/connections present in some areas
- minimize unheeded bends (those beyond spec plans)
where possible
- Suspended & unsupported pipe present in multiple
locations - scribbles marked on site to be
placed prior to backfill in an attempt to add support

C. Pierce KRB
Signature of Environmental Health Specialist

[Signature]
Signature of Recipient

Instructions:

Purpose: This form is developed to be used for making explanatory comments about violations observed during inspections and/or notices of permit actions during inspections of restaurants, foodstands, commissaries, hotels, bed and breakfast homes and inns, summer camps, meat markets, institutions, residential care facilities, public swimming pools, tattoo establishments and other establishments inspected by Environmental Health Specialists under rules adopted by the Commission for Health Services. **Preparation:** local Environmental Health Specialists shall complete form DENR 4008 when necessary during inspections and or notices of permit actions. The original and two copies will be distributed with the form about which they provide comments. **Disposition:** This form may be destroyed in accordance with Standard &, Inspection Records of the Records Disposition Schedule published in the N.C. Division of Archives and History.

Additional Forms may be ordered from: Division Of Environmental Health 1630 Mail Service Center, Raleigh, NC 27699-1630 (Courier 52-01-00)

Environmental Health Services Section (Review 10/06)

DENR 4008 - Revised 10/04

Environmental Health Services Section (Review 10/07)