

Leap of Faith Academy, III
Dawanda Burrus
804 W. Broad St.
Dunn, NC 28334

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546
ph: 910-893-7550
fax: 910-893-9429

Dear Ms. Burrus,

An application for the purposed child care, located at 804 W. Broad St. Dunn, NC, was received and has been reviewed. At this time additional information is requested in order to complete the plan review. Please provide the following:

1. Provide a list of equipment in the kitchen and a corresponding equipment specification sheet for each piece of equipment.
2. Provide a drawing of the child care facility including placement of equipment, storage areas, food service areas, can wash facility. Identify the age groups that will be using the classrooms.
3. Walls and ceilings in rooms in which food is stored, handled, or prepared, utensil-washing rooms and toilet rooms shall be nonabsorbent.
4. Shielded or shatterproof bulbs shall be used in food preparation, storage, and serving areas and in all rooms used by children.
5. A can wash facility shall include a faucet with a threaded nozzle that delivers water of at least 80 degrees Fahrenheit. The faucet shall be located in either a designated utility sink or above a curbed impervious pad that is sloped to drain into an approved sewer system.
6. A separate handwashing sink from the dish sink is required in the kitchen. Indicate the location of the handsinks on the drawing. Additional handsinks may be required outside of those in bathrooms.

Please submit the requested information to Harnett County Central Permitting or to djohnson@harnett.org.

Sincerely,

Jamie Turlington, REHS
Harnett County Health Dept.
Harnett County Environmental Health
(910) 893-7547