



Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

AMAT Psychosocial Rehabilitation Center
1903-B W. Cumberland St.
Dunn, NC 28334

To whom it may concern,

A plan review application was received by this office concerning the construction of the above referenced facility. The application is not approved at this time. Additional information is needed and is detailed below:

- Items on application left blank shall be completed. These include proposed number of participants and number of employees.
- A complete and detailed menu with corresponding food process sheets was not submitted.
- The floor plan submitted was not detailed with respect to placement of equipment in the facility including storage, laundry, kitchen facilities, trash can wash facilities as well as detailed use of rooms.
- Please indicate what type of license you are pursuing and which State licensing agent you are working with. Include the licensing agent's contact information.

The information requested is required for the Plan Review to continue.

Any item not shown on the plans or referenced above will be required to comply with 15A NCAC 18A .3300, "**Rules Governing the Sanitation of Adult Day Service Facilities**". This review does not cover any other aspects of construction regulated by other jurisdictions.

If you require further assistance, please call 910-893-7547.

Sincerely,

Cindy Pierce, REHS
Environmental Health Section
Harnett County Health Department