

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550

fax: 910-893-9429

October 24, 2025

Jacob Godwin
1003 N. General Lee Ave.
Dunn, NC 28334

RE: Rumble Pizza

Dear Mr. Godwin,

A plan review application was received by this office concerning the above referenced facility. The application is approved with the following comments:

- A walk-through, completed October 23, 2025, resulted in a revision to the submitted plans. The revisions, as submitted to Environmental Health, are approved.
- Appropriate splash guards and sneeze guards or partitions shall be required in any area where potential contamination may occur. All guards shall be constructed so that they are smooth, non-absorbent and easily cleanable.
- Cabinets or bar areas which are constructed shall be tight and free of gaps or cracks and also have easily cleanable finishes.
- Deliveries and menu offerings must be at a frequency to manage within the limitations of storage and cold capacity.

Any item not shown on the plans or referenced above will be required to comply with 15A NCAC 18A .2600, **"Rules Governing the Sanitation of Food Service Establishments"** and the **2017 NC Food Code**. This review does not cover any other aspects of construction regulated by other jurisdictions.

If you require further assistance, please call 910-893-7547.

Sincerely,



Cindy Pierce, REHS
Environmental Health Section
Harnett County Health Department