



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

9/14/2021

SUBJECT: EMRES2005-0036
E MECHANICAL RESIDENTIAL

To: COMFORT FIRST HVAC

Here are the results of all Inspections located at **42 RACQUET CT:**

Inspection Type: FINAL**
Scheduled Date/Time: 11/6/2020
Completed Date/Time: 11/6/2020
Inspector: Slade Burton Lawson III
Result: CANCELLED
Remarks: eTRAKiT Inspection Request
Notes: 11/4/2020 7:56 AM COMFORT FIRST HVAC
Scheduled time must be after 1:00pm.
Contact Name: COMFORT FIRST HVAC
Site Address: 42 RACQUET CT
Phone: 9195695161
e-Mail: INSTALLATION@YOURCOMFORTFIRST.COM

Inspection Type: FINAL**
Scheduled Date/Time: 6/17/2021 AM
Completed Date/Time: 6/17/2021
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 6/11/2021 3:31 PM COMFORT FIRST HVAC
please call 910-916-4562 when in route *** text if you can
Contact Name: COMFORT FIRST HVAC
Site Address: 42 RACQUET CT
Phone: 9195695161
e-Mail: installadmin@yourcomfortfirst.com

Inspector SBL changed the inspection assignment from SBL to SPG
Insulate line set at interior unit. Line set condensation causing moisture issues with drywall.





Harnett County
420 Mckinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL**
Scheduled Date/Time: 9/10/2021
Completed Date/Time: 9/10/2021
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: