



Mike Atwood 910-723-2741  
[mike@performancehomesystems.com](mailto:mike@performancehomesystems.com)

Property Address 152 Holly Oak Dr Bunnlevel

HVAC Contractor Comfort First

HVAC System Number

**Data Collection**

Describe area of home served:

CFM25 Total: 61

Conditioned Floor Area (CFA) Served by System: 1648 1 1 1

*(CFM25 x 100 divided by CFA = CFM25/100SF*

**CFM25/100sf 3.70**

**Tester Information**

Company Name Performance Home Systems

Name of Tester Michael Atwood

Tester Certification Envelop Professional

Tester Certification ID BPI ID# 5028752

Equipment ID

Gauge Name/Serial DG700 sn-34393-7-700

Fan Serial 11643

Date of Calibration 11/15/2020

Energy Efficiency Cetrification

CFM50

Conditioned Floor Area (CFA) Served by System:

Room Height

Conditioned Volume Area (CVA) Served by System:

0.30 CFM50/SFSA

5 ACH50

# ENERGY EFFICIENCY CERTIFICATE

401.9

Builder, Permit Holder or Registered Design Professional

Print Name: Comfort First

Signature:

Property Address:

152 Holly Oak Dr Bunnlevel

## Insulation Rating - List the value covering largest area to all that apply

Ceiling/Roof	R-
Wall	R-
Floor	R-
Closed Crawl Space Wall	R-
Closed Crawl Space Floor	R-
Slab	R-
Basement Wall	R-

## Fenestration:

U-Factor	
Solar Heat Gain Coefficient (SHGC)	

## Building Air Leakage

ACH50 (Target 5.0)	
CFM50/SFSA (Target .30)	

Name of Tester - Company	Performance Home Systems
Michael Atwood 30-Nov-20	Envelop Professional BPI ID# 5028752 910-723-2741

## DUCTS

<b>Insulation</b>	<b>R-8</b>
Total Duct Leakage Test Result (sec.403.2.2)	<b>3.70</b>
CFM25 Total /100SF [Target 6]	
CFM25 Total /100SF [Target 6]	
CFM25 Total /100SF [Target 6]	

Name of Tester - Company	Performance Home Systems
Michael Atwood 30-Nov-20	Envelop Professional BPI ID# 5028752 910-723-2741



Performance Home Systems  
Mike Atwood  
Building Analyst  
910-723-2741

[mike@performancehomesystems.com](mailto:mike@performancehomesystems.com)

crawl