



# Permit Inspections Harnett County

**Permit Number: EMRES2207-0040**

Description: **c/o & r/c 3.5 Ton HP & AH 10KW - Attic/Whole Zoned -**

Applied: **7/28/2022**

Approved: **7/28/2022**

Site Address: **164 VALLEY STREAM RD**

Issued: **8/10/2022**

Finalized: **9/29/2022**

City, State Zip Code: **SPRING LAKE, NC 28390**

Status: **FINALED**

Applicant: **COMFORT FIRST HVAC**

Parent Permit:

Owner: **SWAIN DONOVAN**

Parent Project:

Contractor: **COMFORT FIRST HVAC**

Details:

### LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
	8/16/2022	8/16/2022	FINAL**	John B Kokoszka	DISAPPROVED	eTRAKiT Inspection Request
Notes: 8/10/2022 3:01 PM COMFORT FIRST HVAC Please call in route 773-510-8236 AM requested Contact Name: COMFORT FIRST HVAC Site Address: 164 VALLEY STREAM RD Phone: 9195695161 e-Mail: installadmin@yourcomfortfirst.com  Pan full of water. Leaking from unit.Float switch not working because the unit is still running Pan full of water. Leaking from unit.Float switch not working because the unit is still running						
	8/24/2022	8/24/2022	FINAL**	James T Hall	CANCELLED	eTRAKiT Inspection Request
Notes: 8/17/2022 12:05 PM COMFORT FIRST HVAC requests am - please call 773-510-8236 in route Contact Name: COMFORT FIRST HVAC Site Address: 164 VALLEY STREAM RD Phone: 9195695161 e-Mail: installadmin@yourcomfortfirst.com  canceled by Paige Mitchell						
	9/29/2022	9/29/2022	FINAL**	John B Kokoszka	APPROVED	am preferred
Notes: am preferred						

