



Scott E. Wyssling, PE
 Coleman D. Larsen, SE, PE
 Gregory T. Elvestad, PE

76 North Meadowbrook Drive
 Alpine, UT 84004
 office (201) 874-3483
 swyssling@wysslingconsulting.com

November 2, 2022

Scott
 Wyssling, PE

Digitally signed by Scott Wyssling, PE
 DN: C=US, S=Utah, L=Alpine, O=Wyssling
 Consulting, OU=Owner, CN="Scott Wyssling,
 PE", E=swyssling@wysslingconsulting.com
 Reason: I am the author of this document
 Location: your signing location here
 Date: 2022.11.02 15:00:01-06'00'
 Foxit PDF Editor Version: 11.1.0

LGCY Solar
 3333 Digital Drive #600
 Lehi, UT 84043

Re: Engineering Services
 Raynor Residence
 107 Paul Clayton Circle COATS, NC
 8.360 kW System

To Whom it May Concern,

Pursuant to your request, we have reviewed the following information regarding ground mount solar panel installation at the above referenced location:

1. Product documentation prepared by IronRidge Corp detailing the IronRidge ground mount system being utilized for the proposed ground mount system.
2. Design drawings of the proposed system including a site plan, and details for the solar panels. This information was prepared by Legacy Solar and will be utilized for approval and construction of the proposed system.


Based on our review of the Photovoltaic Array installed at 4 modules high and 5 modules wide. The PV array shall have a pier spacing of 9' max North/South and 6' East/West. Based on a wind speed of 110 mph, Exposure C and a ground snow load of 20 PSF, it was determined that the minimum required footing depth is 4' below grade with a 16" diameter pier footing with 2" Dia schedule 40 post. The footing size based upon the worst case loading due to horizontal and vertical wind loading.

Based on the above evaluation, it is the opinion of this office that with appropriate construction the footing and post assembly will adequately support the proposed solar array. This evaluation is in conformance with the 2018 IBC, current industry and standards, and based on information supplied to us at the time of this report.

This certification is specific to the footing design for the solar system and does not include the racking system. Racking system and components designed and specified by the manufacturer (IronRidge).

Should you have any questions regarding the above or if you require further information do not hesitate to contact me.

Very truly yours,


 Scott E. Wyssling, PE
 North Carolina License No. 46546



Wyssling Consulting, PLLC
 76 N Meadowbrook Drive Alpine UT 84004
 North Carolina COA # P-2308

11/2/2022

THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

SCOPE OF WORK:
 TO INSTALL A GROUND MOUNTED SOLAR PHOTOVOLTAIC SYSTEM AT THE OWNER RESIDENCE LOCATED AT 107 PAUL CLAYTON CIR COATS, NC 27521.
 THE POWER GENERATED BY THE PV SYSTEM WILL BE INTERCONNECTED WITH THE UTILITY GRID THROUGH THE EXISTING ELECTRICAL SERVICE EQUIPMENT.
 THE PV SYSTEM DOES NOT INCLUDE STORAGE BATTERIES

EQUIPMENT SUMMARY

19 APTOS SOLAR DNA-120-MF10-440 MODULES
19 ENPHASE IQ8PLUS-72-2-US MICROINVERTERS

GOVERNING CODES

2017 NATIONAL ELECTRICAL CODE
2018 INTERNATIONAL FIRE CODE
2018 INTERNATIONAL BUILDING CODE
2018 INTERNATIONAL RESIDENTIAL CODE
2018 NORTH CAROLINA STATE BUILDING CODE
AUTHORITY HAVING JURISDICTION (AHJ): HARNETT COUNTY

SYSTEM RATING

8.36 KWDC
5.51 KWAC

SHEET INDEX


PV-0	COVER PAGE
PV-1	SITE PLAN
PV-2	ROOF-PLAN & MODULES
PV-3	ATTACHMENT DETAIL
PV-4	ELECTRICAL LINE DIAGRAM & CALCS.
PV-4A	ELECTRICAL PHOTOS
PV-4B	SPECIFICATIONS & CALCULATION
PV-5	LABELS
PV-5A	JOB HAZARD ANALYSIS
PV-6+	EQUIPMENT SPECIFICATIONS

- GENERAL NOTES:**
- THESE CONSTRUCTION DOCUMENTS HAVE BEEN BASED ON FIELD INSPECTIONS AND OTHER INFORMATION AVAILABLE AT THE TIME. ACTUAL FIELD CONDITIONS MAY REQUIRE MODIFICATIONS IN CONSTRUCTION DETAILS.
 - ARCHITECT HAS NOT BEEN RETAINED TO SUPERVISE ANY CONSTRUCTION OR INSTALLATION OF ANY EQUIPMENT AT SITE.
 - CONTRACTOR SHALL FURNISH ALL LABOR, MATERIAL, EQUIPMENT, TOOLS, OBTAINS ALL PERMITS, LICENSES AND PAY ALL REQUIRED FEES AND COMPLETE INSTALLATION.
 - CONTRACTOR HAS THE FULL RESPONSIBILITY TO CHECK AND VERIFY ALL DIMENSIONS AND EXISTING CONDITIONS. ANY DISCREPANCIES SHALL BE REPORTED TO THE ENGINEER BEFORE PROCEEDING WITH THE WORK. ANY WORK STARTED BEFORE CONSULTATION AND ACCEPTANCE BY THE ENGINEER SHALL BE THE SOLE RESPONSIBILITY OF THE CONTRACTOR AND SHALL BE SUBJECT TO CORRECTION BY THEM WITHOUT ADDITIONAL COMPENSATION.
 - DAMAGE CAUSED TO THE EXISTING STRUCTURE, PIPES, DUCTS, WINDOWS, WALL, FLOORS, ETC. SHALL BE REPAIRED TO THE ORIGINAL CONDITION OR REPLACED BY THE CONTRACTOR AT NO ADDITIONAL COST.
 - THE CONTRACTOR SHALL BE HELD RESPONSIBLE FOR THE PROPER INSTALLATION AND COMPLETION OF THE WORK WITH APPROVED MATERIALS.
 - NO CHANGES ARE TO BE MADE WITHOUT THE CONSULTATION AND APPROVAL OF THE ARCHITECT.
 - CONTRACTOR SHALL OBTAIN BUILDING PERMIT. NO WORK TO START UNLESS BUILDING PERMIT IS PROPERLY DISPLAYED.
 - ALL WORKMANSHIP AND MATERIALS SHALL BE OF FIRST QUALITY AND IN COMPLIANCE WITH THE REQUIREMENTS OF THE NC BUILDING CODE, THE DEPARTMENT OF ENVIRONMENTAL PROTECTION AND ALL PERTINENT AGENCIES.
 - IT IS ESSENTIAL THAT ALL WORK PROCEED WITH THE MAXIMUM COOPERATION OF ALL PARTIES AND WITH MINIMUM INTERFERENCE TO THE OCCUPANTS WITHIN THE BUILDING.
 - THE OWNER'S DIRECTIONS IN THIS REGARD SHALL BE FULLY COMPLIED WITH.
 - ALL EXPOSED PLUMBING, HVAC, ELECTRICAL DUCTWORK, PIPING AND CONDUITS ARE TO BE PAINTED BY GENERAL CONTRACTOR.
 - THE CONTRACTOR SHALL PERFORM THE WORK IN STRICT CONFORMANCE WITH THE LOCAL LAWS, REGULATIONS AND THE NATIONAL ELECTRIC CODE.
 - THE CONTRACTOR SHALL OBTAIN ALL PERMITS, APPROVALS, AFFIDAVITS, CERTIFICATIONS, ETC. AND PAY ALL FEES AS REQUIRED BY THE LOCAL AUTHORITIES.
 - CONTRACTORS SHALL OBTAIN FIRE CERTIFY UPON COMPLETION OF WORK.

- ELECTRICAL NOTES:**
- THE EQUIPMENT AND ALL ASSOCIATED WIRING AND INTERCONNECTION SHALL BE INSTALLED ONLY BY QUALIFIED PEOPLE. A QUALIFIED PERSON IS ONE WHO HAS SKILLS AND KNOWLEDGE RELATED TO THE CONSTRUCTION AND OPERATION OF THE ELECTRICAL EQUIPMENT AND INSTALLATIONS AND HAS RECEIVED SAFETY TRAINING TO RECOGNIZE AND AVOID THE HAZARDS INVOLVED. (NEC 690.4(E) AND 705.6)
 - LOCAL UTILITY PROVIDER SHALL BE NOTIFIED PRIOR TO USE AND ACTIVATION OF ANY SOLAR PHOTOVOLTAIC INSTALLATION. FOR A LINE SIDE TAP CONNECTION, UTILITY NEEDS TO BE NOTIFIED WELL IN ADVANCE TO COORDINATE BUILDING ELECTRICAL SHUT OFF.
 - NEW CONDUIT ROUTING SHOWN IS ESSENTIALLY SCHEMATIC. SUBCONTRACTOR SHALL LAY OUT RUNS TO SUIT FIELD CONDITIONS AND THE COORDINATION REQUIREMENTS OF OTHER TRADES.
 - ARRAY WIRING SHOULD NOT BE READILY ACCESSIBLE EXCEPT TO QUALIFIED PERSONNEL.
 - ALL EXTERIOR CONDUIT, FITTINGS, AND BOXES SHALL BE WATERTIGHT AND APPROVED FOR USE IN WET LOCATIONS. (NEC 314.15A).
 - WIRING METHODS FOR PV SYSTEM CONDUCTORS AREN'T PERMITTED WITHIN 10 IN. OF THE ROOF DECKING OR SHEATHING EXCEPT WHERE LOCATED DIRECTLY BELOW THE ROOF SURFACE THAT'S COVERED BY PV MODULES AND ASSOCIATED EQUIPMENT WIRING
 - BACK-FED BREAKER MUST BE AT THE OPPOSITE END OF BUS BAR FROM THE MAIN BREAKER OR MAIN LUG SUPPLYING CURRENT FROM THE UTILITIES.
 - ALL CONDUCTORS AND WIRE TIES EXPOSED TO SUNLIGHT ARE LISTED AS UV RESISTANT.
 - CONTRACTOR SHALL FOLLOW ALL ELECTRICAL EQUIPMENT LABELING REQUIREMENTS IN NEC 690 AND IFC 2018
 - MEASURE THE LINE-TO-LINE AND LINE-TO-NEUTRAL VOLTAGE OF ALL SERVICE ENTRANCE CONDUCTORS PRIOR TO INSTALLING ANY SOLAR EQUIPMENT. THE VOLTAGES FOR THE 240VAC RATED.



1 HOUSE PHOTO
 PV-0 SCALE: NTS



2 VICINITY MAP
 PV-0 SCALE: NTS

LGCCY POWER
 LGCCY POWER
 3333 DIGITAL DR#600, LEHI,
 UT 84043, UNITED STATES
 PHONE: 855-353-4899



Wyssling Consulting, PLLC
 1701 N. Missionbrook Drive Alpine UT 84004
 North Carolina COA # P-2308
 11/12/2022

ALL INFORMATION CONTAINED HEREIN IS UNCLASSIFIED EXCEPT WHERE SHOWN OTHERWISE. ALL INFORMATION CONTAINED HEREIN IS UNCLASSIFIED EXCEPT WHERE SHOWN OTHERWISE. ALL INFORMATION CONTAINED HEREIN IS UNCLASSIFIED EXCEPT WHERE SHOWN OTHERWISE.

RICKY RAYNOR
 RESIDENCE
 107 PAUL CLAYTON CIR
 COATS, NC 27521
 PH NO. (919) 625-7661
 EMAIL ID: rmaynor@hammettk12.nc.us

DATE: 11/02/2022
 SHEET NAME
COVER PAGE
 SHEET SIZE
**ANSI B
 11" X 17"**
 SHEET NUMBER
PV-0

LEGACY POWER
 LEGCY POWER
 3333 DIGITAL DR#600, LEHI,
 UT 84043, UNITED STATES
 PHONE: 855-353-4899
Collette R. Subersman 7c
 ELECTRICAL LIC. U.21468




Wysssling Consulting, PLLC
 76 N Meigsbrook Drive Alpine UT 84004
 North Carolina CD # P-2388
 11/2/2022

THIS IS AN ELECTRONIC FILE. ANY CHANGES TO THIS DOCUMENT MUST BE MADE TO THE ORIGINAL FILE. PRINTED COPIES OF THIS DOCUMENT ARE UNRELIABLE. THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

RICKY RAYNOR
 RESIDENCE
 107 PAUL CLAYTON CIR
 COATS, NC 27521
 PH NO. (919) 625-7661
 EMAIL ID: rraynor@harnett.k12.nc.us

DATE: 11/02/2022
SHEET NAME
SITE PLAN
SHEET SIZE
ANSI B 11" X 17"
SHEET NUMBER
PV-1

Digitally signed by Scott Wyssling,
 PE, CA, US, Se Utah, Le Alpine,
 O=Wysssling Consulting
 OU=Owner, CN=Scott Wyssling,
 PE.
 E=swysling@wyssslingconsulting.c
 Reason: I am the author of this
 document.
 Location: your signing location here
 Date: 2022.11.02 15:02:46-00'
 Page PDF Editor Version: 11.1.0



1 | PLOT PLAN WITH ROOF PLAN
 PV-1 | SCALE: 1/32" = 1'-0"




INVERTER SPECIFICATIONS	
MANUFACTURER / MODEL	ENPHASE IQ8PLUS-72-2-US
MAX DC SHORT CIRCUIT CURRENT	15 A
CONTINUOUS OUTPUT CURRENT	1.21A (240V)

DESIGN SPECIFICATION	
RISK CATEGORY:	II
CONSTRUCTION:	SFD
ZONING:	RESIDENTIAL
SNOW LOAD (ASCE 7-16):	20 PSF
EXPOSURE CATEGORY:	C
WIND SPEED (ASCE 7-16):	110 MPH


LEGEND	
IRB	(N) JUNCTION BOX
UM	(E) UTILITY METER
MSP	(E) MAIN SERVICE PANEL (MSP)
SUB	(E) SUBPANEL (SUB)
AC	(N) NON-FUSED AC DISCONNECT
IC	(N) ENPHASE IQ COMBINER 4
○	VENT, ATTIC FAN (ROOF OBSTRUCTION)
●	ROOF ATTACHMENT
---	CONDUIT
□	TOP-CAP
—	PIPE
---	TRENCH

MODULE TYPE, DIMENSIONS & WEIGHT	
NUMBER OF MODULES:	19 MODULES
MODULE TYPE:	APTOS SOLAR DNA-120-MF10-440
MODULE WEIGHT:	52.9 LBS
MODULE DIMENSIONS:	74.92" X 44.65" = 23.23 SF
UNIT WEIGHT OF AREA:	2.28 PSF



ARRAY DESCRIPTION	
ARRAY #1	ARRAY TILT 20°
ARRAY #1	ARRAY TILT 180°
ARRAY AREA CALC'S	
ARRAY #1	# OF MODULES
ARRAY #1	ARRAY AREA (Sq. Ft.)
ARRAY #1	441.37

LGCCY POWER
 LGCCY POWER
 3333 DIGITAL DR#600, LEHI,
 UT 84043, UNITED STATES
 PHONE: 855-353-4899
Collette R. Spawson 7c
 ELECTRICAL LIC. U.21468



Wyssling Consulting, PLLC
 76 N Main Street, Suite 100
 North Carolina CO. # P-2388
 11/2/2022


THIS IS AN UNRECORDED COPY. ANY CHANGES TO THIS DOCUMENT MUST BE MADE ON ANY ELECTRONIC COPIES. ORIGINAL MUST BE KEPT IN ORIGINAL FORM AND NOT REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM.


RICKY RAYNOR
 RESIDENCE
 107 PAUL CLAYTON CIR
 COATS, NC 27521
 PH NO. (919) 625-7661
 EMAIL ID: rraynor@hammettk12.nc.us

DATE: 11/02/2022
SHEET NAME
ROOF PLAN & MODULES
SHEET SIZE
ANSI B 11" X 17"
SHEET NUMBER
PV-2


Digitally signed by Scott Wyssling, DN: cn=Scott Wyssling, o=Wyssling Consulting, ou=Owner, email=Scott.Wyssling@wyssling.com, c=US
 Reason: I am the author of this document and I am signing it at the location here.
 Date: 2022.11.02 15:00:00 PST
 15000 bytes
 PDF GENERATED BY: AutoCAD
 11.1.0

(E) FRONT OF RESIDENCE
 PAUL CLAYTON CIR






A 3-UP - PV SYSTEM PLAN DETAIL
Scale: 1/8"=1'-0"




B 3-UP - PV SYSTEM SIDE SECTION
Scale: NTS


- SHEET NOTES
- SCHEDULE 40 PIPE OR ALLIED MECHANICAL TUBING (12GA WALL THICKNESS)




J DRILL/POUR FOUNDATION
Scale: NTS




K DRIVEN PIER FOUNDATION
Scale: NTS




L HELICAL PILE FOUNDATION
Scale: NTS




C PIPE FITTINGS DETAIL NTS




E DETAIL, MID CLAMP PLAN NTS




G DETAIL, END CLAMP (UFO) PLAN NTS



D PIPE FITTINGS DETAIL NTS




F DETAIL, MID CLAMP FRONT NTS



H DETAIL, END CLAMP (UFO) FRONT NTS

LGCY POWER
 LGCY POWER
 3333 DIGITAL DR#600, LEHI,
 UT 84043, UNITED STATES
 PHONE: 855-353-4899

ELECTRICAL LIC. U.21488



Wyssling Consulting, PLLC
 76 N Midlandbreak Drive Alpine UT 84004
 North Carolina CO# P-2398

11/2/2022

THIS IS AN ELECTRONIC COPY OF THE ORIGINAL DOCUMENT. THE ORIGINAL DOCUMENT IS STORED IN THE PROJECT'S ARCHIVE AND IS AVAILABLE FOR REVIEW AT ANY TIME. THE ORIGINAL DOCUMENT MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

RICKY RAYNOR
 RESIDENCE
 107 PAUL CLAYTON CIR
 COATS, NC 27521
 PH NO. (919) 625-7661
 EMAIL ID: rraynor@hamett.k12.nc.us

DATE: 11/02/2022

SHEET NAME
**ATTACHMENT
 DETAILS**

SHEET SIZE

ANSI B
 11" X 17"

SHEET NUMBER

PV-3

**Scott
 Wyssling, PE**

Digitally signed by Scott
 Wyssling, OU=Scott
 Wyssling, OU=Utah
 L=Alpine, O=Wyssling
 Consulting, OU=Owner,
 CN=Scott Wyssling, PE,
 E=swyssling@wysslingco
 .com, OU=Scott Wyssling
 Consulting, OU=Owner,
 Location: your signing
 location here, O=OZ
 Date: 2022.10.02
 Time: 16:27:00
 Foxit PDF Editor, Version:
 11.1.0

REVISIONS	DESCRIPTION	DATE	REV
REVISION	09/20/2022	A	
REVISION	11/02/2022	B	

Signature with Seal

PROJECT NAME & ADDRESS
RICKY RAYNOR RESIDENCE
 107 PAUL CLAYTON CIR
 COATS, NC 27521
 PH NO. (919) 625-7661
 EMAIL ID: rraynor@harnett.k12.nc.us

DATE: 11/02/2022


SHEET NAME
ELECTRICAL LINE & CALCS.

SHEET SIZE
**ANSI B
 11" X 17"**

SHEET NUMBER
PV-4

ID	TYPICAL	INITIAL CONDUCTOR LOCATION	FINAL CONDUCTOR LOCATION	CONDUCTOR	CONDUIT	# OF PARALLEL CIRCUITS	CURRENT-CARRYING CONDUCTORS IN CONDUIT	CONDUIT FILL PERCENT	OCPD	EGC	TEMP. CORR. FACTOR	CONDUIT FILL FACTOR	CONT. CURRENT	MAX. CURRENT	BASE AMP.	DERATED AMP.	TERM. TEMP. RATING	LENGTH	VOLTAGE DROP
1	2	BRANCH	JUNCTION BOX	12 AWG Q CABLE	-	1	2	N/A	N/A	6 AWG COPPER	0.71 (95°C)	N/A	12.1A	15.1A	N/A	75°C	55FT	0.46%	
2	1	JUNCTION BOX	IQ COMBINER BOX	10 AWG THWN-2 COPPER	MIN 0.75" Dia EMT	2	4	19.09%	20A	10 AWG THWN-2 COPPER	0.96 (34°C)	0.8	12.1A	15.1A	40A	75°C	5FT	0.07%	
3	1	IQ COMBINER BOX	NON-FUSED AC DISCONNECT	6 AWG THWN-2 COPPER	MIN 0.75" Dia PVC	1	3	36.77%	N/A	10 AWG THWN-2 COPPER	0.96 (34°C)	1	23.0A	28.7A	75A	75°C	85FT	0.80%	
4	1	NON-FUSED AC DISCONNECT	MSP	6 AWG THWN-2 COPPER	MIN 0.75" Dia EMT	1	3	36.77%	30A	10 AWG THWN-2 COPPER	0.96 (34°C)	1	23.0A	28.7A	75A	75°C	5FT	0.05%	

NOTE:- WIRE BETWEEN JB WILL FLOW INSIDE THE ATTIC



INTERCONNECTION
 120% RULE - NEC 705.12(B)(2)(3)(d)
 UTILITY FEED + SOLAR BACKFEED
 200 A + 30A = 230A
 BUS RATING x 120%
 200 A x 120% = 240A

SERVICE INFO
 UTILITY PROVIDER: DUKE ENERGY PROGRESS
 MAIN SERVICE VOLTAGE: 240V
 MAIN CIRCUIT BREAKER RATING: 200A
 MAIN SERVICE PANEL: 200A
 MAIN SERVICE LOCATION: NORTH
 SERVICE FEED SOURCE: UNDERGROUND

1 | ELECTRICAL LINE DIAGRAM
 PV-4 | SCALE: NTS

LGCY POWER
 LGCY POWER
 3333 DIGITAL DR#600, LEHI,
 UT 84043, UNITED STATES
 PHONE: 855-353-4899
Collette R. Swanson
 ELECTRICAL LIC. U.21498

REVISIONS			
DESCRIPTION	DATE	REV	
REVISION	09/20/2022	A	
REVISION	11/02/2022	B	

Signature with Seal


PROJECT NAME & ADDRESS
**RICKY RAYNOR
 RESIDENCE**
 107 PAUL CLAYTON CIR
 COATS, NC 27521
 PH NO. (919) 625-7661
 EMAIL ID: rraynor@harnett.k12.nc.us

DATE: 11/02/2022

SHEET NAME
**ELECTRICAL
 PHOTOS**

SHEET SIZE
**ANSI B
 11" X 17"**

SHEET NUMBER
PV-4A



SOLAR MODULE SPECIFICATIONS	
MANUFACTURER / MODEL	APTOS SOLAR DNA-120-MIF10-440
VMP	33.82 V
IMP	13.01 A
VOC	40.8V
ISC	13.61A
TEMP. COEFF. VOC	-0.31%/°K
MODULE DIMENSION	74.92" (L) x 44.65" (W)
MODULE PTC RATING	406 W
PANEL WATTAGE	440W

INVERTER SPECIFICATIONS	
MANUFACTURER / MODEL	ENPHASE IQ8PLUS-72-2-US
MAX DC SHORT CIRCUIT CURRENT	15 A
CONTINUOUS OUTPUT CURRENT	1.21A (240V)

AMBIENT TEMPERATURE SPECS	
RECORD LOW TEMP	-12°C
AMBIENT TEMP (HIGH TEMP 2%)	34°C
CONDUIT HEIGHT	7/8"
ROOF TOP TEMP	90°C
CONDUCTOR TEMPERATURE RATE	56°C
MODULE TEMPERATURE COEFFICIENT OF VOC	-0.29%/°K

PERCENT OF VALUES	NUMBER OF CURRENT CARRYING CONDUCTORS IN LEMT
0.80	4-6
0.70	7-9
0.50	10-20

Voltage rise in Q Cable from the Microinverters to the Junction Box

For branch circuit #1 of 10 IQ 8+Micros, the voltage rise on the 240 VAC Q Cable is 0.46%
 For branch circuit #2 of 09 IQ 8+Micros, the voltage rise on the 240 VAC Q Cable is 0.38%

Voltage rise from the Junction Box to the IQ Combiner box

$VRise = (\text{amps/inverter} \times \text{number of inverters}) \times (\text{resistance in } \Omega/\text{ft}) \times (2\text{-way wire length in ft.})$
 $= (1.21 \text{ amp} \times 10) \times (0.00129 \Omega/\text{ft}) \times (5 \text{ ft} \times 2)$
 $= 12.1 \text{ amps} \times 0.00129 \Omega/\text{ft} \times 10 \text{ ft}$
 $= 0.16 \text{ volts}$
 $\%VRise = 0.16 \text{ volts} \div 240 \text{ volts} = 0.07\%$
 The voltage rise from the Junction Box to the IQ Combiner Box is 0.07%

Voltage rise from the IQ Combiner box to AC Disconnect

$VRise = (\text{amps/inverter} \times \text{number of inverters}) \times (\text{resistance in } \Omega/\text{ft.}) \times (2\text{-way wire length in ft.})$
 $= (1.21 \text{ amp} \times 19) \times (0.000491 \Omega/\text{ft}) \times (85 \text{ ft.} \times 2)$
 $= 23.0 \text{ amps} \times 0.000491 \Omega/\text{ft} \times 170 \text{ ft.}$
 $= 1.91 \text{ volts}$
 $\%VRise = 1.91 \text{ volts} \div 240 \text{ volts} = 0.80\%$
 The voltage rise from the IQ Combiner Box to the AC Disconnect is 0.80%

Voltage rise from the AC Disconnect to the MSP

$VRise = (\text{amps/inverter} \times \text{number of inverters}) \times (\text{resistance in } \Omega/\text{ft.}) \times (2\text{-way wire length in ft.})$
 $= (1.21 \text{ amp} \times 19) \times (0.000491 \Omega/\text{ft}) \times (5 \text{ ft.} \times 2)$
 $= 23.0 \text{ amps} \times 0.000491 \Omega/\text{ft} \times 10 \text{ ft.}$
 $= 0.11 \text{ volts}$
 $\%VRise = 0.11 \text{ volts} \div 240 \text{ volts} = 0.05\%$
 The voltage rise from the AC Disconnect to the MSP is 0.05%

Total system voltage rise for all three wire sections

$0.46\% + 0.07\% + 0.80\% + 0.05\% = 1.38\%$

LGCY POWER
 LGCY POWER
 3333 DIGITAL DR#600, LEHI,
 UT 84043, UNITED STATES
 PHONE: 855-353-4899

Colin R. Spawson Jr.
 ELECTRICAL LIC. U.21498

REVISIONS	DESCRIPTION	DATE	REV
	REVISION	09/20/2022	A
	REVISION	11/02/2022	B

Signature with Seal

PROJECT NAME & ADDRESS
 RICKY RAYNOR
 RESIDENCE
 107 PAUL CLAYTON CIR
 COATS, NC 27521
 PH NO. (919) 625-7661
 EMAIL ID: rraynor@harnett.k12.nc.us

DATE: 11/02/2022

SHEET NAME
SPECIFICATION & CALCS.

SHEET SIZE

ANSI B
 11" X 17"

SHEET NUMBER

PV-4B

LOGGY POWER
 LOGGY POWER
 3333 DIGITAL DR#600, LEHI,
 UT 84043, UNITED STATES
 PHONE: 855-353-4899

Charles R. Swanson Jr.
 ELECTRICAL LIC. U.21498

REVISIONS	DESCRIPTION	DATE	REV
REVISION	09/20/2022	A	
REVISION	11/02/2022	B	

Signature with Seal

PROJECT NAME & ADDRESS
RICKY RAYNOR RESIDENCE
 107 PAUL CLAYTON CIR
 COATS, NC 27521
 PH NO. (919) 625-7661
 EMAIL ID: mraynor@harnett.k12.nc.us

DATE: 11/02/2022
 SHEET NAME
LABELS
 SHEET SIZE
ANSI B 11" X 17"
 SHEET NUMBER
PV-5

CAUTION
 DUAL POWER SOURCE
 SECOND SOURCE US
 PHOTOVOLTAIC

LABEL LOCATION:
 MAIN SERVICE DISCONNECT, AC DISCONNECT/
 MAIN SERVICE PANEL/ REVENUE METER/ AC
 COMBINER
 PER CODE: NEC 705.12(B)(3)

**PHOTOVOLTAIC SYSTEM
 UTILITY DISCONNECT SWITCH**

LABEL LOCATION:
 AC DISCONNECT
 2017 NEC 690.56(C)(3)

9

**CAUTION: SOLAR ELECTRIC
 SYSTEM CONNECTED**

LABEL LOCATION:
 POINT OF INTERCONNECTION & INVERTER
 PER CODE: NEC 690.15 & 690.13(B)

WARNING - Electric Shock Hazard
 No user serviceable parts inside
 Contact authorized service provider for assistance

LABEL LOCATION:
 INVERTER & JUNCTION BOXES (ROOF)
 PER CODE: NEC 690.13 (G)(3) & 690.13 (G)(4)

10

**WARNING: PHOTOVOLTAIC
 POWER SOURCE**

LABEL LOCATION:
 CONDUIT
 PER CODE: 2017 NEC 690.31(G)(3)

6

PHOTOVOLTAIC SYSTEM AC DISCONNECT
 RATED AC OUTPUT CURRENT 23.0 AMPS
 NOMINAL OPERATING AC VOLTAGE 240 VOLTS

LABEL LOCATION:
 MAIN SERVICE PANEL/MAIN SERVICE DISCONNECT/AC DISCONNECT
 PER CODE: NEC 690.13(B)

7

WARNING
ELECTRICAL SHOCK HAZARD
 TERMINALS ON BOTH LINE AND
 LOAD SIDES MAY BE ENERGIZED
 IN THE OPEN POSITION

LABEL LOCATION:
 POINT OF INTERCONNECTION, MAIN SERVICE
 DISCONNECT, AC DISCONNECT, AC COMBINER,
 INVERTER
 PER CODE: NEC 690.13(B)

8

WARNING
**INVERTER OUTPUT CONNECTION DO NOT
 RELOCATE THIS OVERCURRENT DEVICE**

LABEL LOCATION:
 INVERTER LABEL AT P.O.C. TO SERVICE DISTRIBUTION
 EQUIPMENT (I.E. MAIN PANEL (AND SUBPANEL IF
 APPLICABLE))
 PER CODE: NEC705.12(D)(2)(b)

4

**SOLAR PV SYSTEM EQUIPPED
 WITH RAPID SHUTDOWN**

TURN RAPID SHUTDOWN
 SWITCH TO "OFF" POSITION TO
 SHUT DOWN PV SYSTEM
 AND REDUCE
 SHOCK HAZARD
 IN THE ARRAY

LABEL LOCATION:
 MAIN SERVICE DISCONNECT IF MSD IS OUTSIDE
 PLACE IT THERE / IF MSD IS INSIDE PLACE ON THE
 AC DISCONNECT
 PER CODE: NEC 690.56(C)(1)(a)

5

CAUTION: SOLAR CIRCUIT

LABEL LOCATION:
 MARKINGS PLACED ON ALL INTERIOR AND EXTERIOR CONDUIT, RACEWAYS,
 ENCLOSURES, AND CABLE ASSEMBLIES AT LEAST EVERY 10 FT. AT TURNS AND
 ABOVE/BELow PENETRATIONS AND ALL COMBINER/JUNCTION BOXES
 PER CODE: IPC 606.11.1.4

CAUTION
 POWER TO THIS BUILDING IS SUPPLIED FROM
 THE FOLLOWING SOURCES WITH DISCONNECTS
 LOCATED AS SHOWN

PAUL CLAYTON CIR

ADHESIVE FASTENED SIGNS:
 • ANSIZ535.4-2011 PRODUCT SAFETY SIGNS AND LABELS, PROVIDES GUIDELINES FOR SUITABLE FONT SIZES, WORDS, COLORS, SYMBOLS, AND LOCATION REQUIREMENTS FOR LABELS. NEC 110.21(B)(1).
 • THE LABEL SHALL BE OF SUFFICIENT DURABILITY TO WITHSTAND THE ENVIRONMENT INVOLVED. NEC 110.21(B)(3).
 • ADHESIVE FASTENED SIGNS MAY BE ACCEPTABLE IF PROPERLY ADHERED. VINYL SIGNS SHALL BE WEATHER RESISTANT.



FIELD DESIGN REQUEST FORM

JOB INFORMATION

JOB NAME: _____

ADDRESS: _____

CHANGE REQUEST:

WHO AUTHORIZED THE CHANGE: _____

DESCRIBE THE NEEDED CHANGE & WHY: _____

NEW DESIGN LAYOUT:

DRAW THE MOUNTING PLANE SHOWING THE NEW MODULE LAYOUT:

INSTALLER NAME (PRINT) _____

I UNDERSTAND AND AGREE TO THE CHANGES MADE ABOVE

CUSTOMER NAME _____ CUSTOMER SIGNATURE _____ DATE _____



JOB HAZARD ANALYSIS

CUSTOMER NAME/JOB ID: _____

CUSTOMER ADDRESS: _____

INSTALL DATE: _____ TIME: _____ am/pm

HAZARD CATEGORY	HAZARD TYPE	HAZARD CONTROL MEASURES
LADDER SAFETY	<ul style="list-style-type: none"> LOCATION CONDITION WORKING CLEARANCE 	
FALL PROTECTION	<ul style="list-style-type: none"> WORKING 6' OR HIGHER 	
ELECTRICAL SAFETY	<ul style="list-style-type: none"> ARCH FLASH ELECTRIC SHOCK/ELECTROCUTION 	
WEATHER CONDITIONS	<ul style="list-style-type: none"> HEAT/COLD TEMP RAINY/WINDY 	
PUBLIC SAFETY	<ul style="list-style-type: none"> WORK/OBJECTS OVERHEAD SLIPS/TRIPS/FALLS ACCESS TO LIVE ELECTRICAL 	

NEAREST EMERGENCY FACILITY _____

CONTACT IMMEDIATELY IN EMERGENCY (911 AND/OR) _____

GENERAL SITE DESCRIPTION/NOTES

CREW MEMBERS ON SITE FOR INSTALL

NAME	SIGNATURE
FMU/LMD-	

ELECTRICAL COMPLETION PHOTOS QR CODE

ROOFTOP INSTALLATION PHOTOS QR CODE

MPU COMPLETION PHOTOS QR CODE

LGCY POWER

LGCY POWER
 3333 DIGITAL DR#600, LEHI,
 UT 84043, UNITED STATES
 PHONE: 855-353-4899

Collette R. Swanson Jr.
 ELECTRICAL LIC. U.21498

REVISIONS

DESCRIPTION	DATE	REV
REVISION	09/20/2022	A
REVISION	11/02/2022	B

Signature with Seal _____

PROJECT NAME & ADDRESS

RICKY RAYNOR RESIDENCE
 107 PAUL CLAYTON CIR
 COATS, NC 27521
 PH NO. (919) 625-7661
 EMAIL ID: mraynor@harnett.k12.nc.us

DATE: 11/02/2022

SHEET NAME
JOB HAZARD ANALYSIS


SHEET SIZE
**ANSI B
 11" X 17"**

SHEET NUMBER
PV-5A

DNA™ 120

Solar for Innovators

Residential | Commercial



Features



Advanced Technology
Patented DNA™ technology boosts power performance & module efficiency



Maximum Panel Density
Advanced split cell technology with 9 ultra-thin busbars allows for less resistance and more photon capture



Durable Design
Robust product design is resilient in extreme weather. Up to 5400 Pa snow load and 5400 Pa wind load




A Safe Investment
Industry leading 30 year warranty

Designed & Engineered in Silicon Valley



440W | 435W | 430W

Our DNA Split Cell Series uses advanced selective emitter PERC technology with thin film layers to improve heat tolerance, increase photon capture, minimize resistive loss, and use 5% more of the available active area for optimal power performance. Our panels exceed IEC standards and come with an industry leading, 30-year warranty.

Linear Performance Warranty



DNA™ 120



Electrical Specifications	DNA-120-HP10-440W	DNA-120-HP10-445W	DNA-120-HP10-430W
STC Rated Output P_{max} (W)	440W	445W	450W
Module Efficiency	20.39%	20.62%	20.85%
Open Circuit Voltage V_{oc} (V)	40.80	41.10	41.34
Short Circuit Current I_{sc} (A)	13.61	13.70	13.80
Rated Voltage V_{max} (V)	33.82	34.02	34.16
Rated Voltage V_{nom} (V)	13.01	13.09	13.17


Standard Test Conditions for front face of panel: 1000 W/m² Irr. 25°C measurement uncertainty ±5%

Temperature Coefficients	Value
Temperature Coefficients P_{max}	-0.35%/°C
Temperature Coefficients V_{oc}	+0.06%/°C
Temperature Coefficients I_{sc}	-0.31%/°C
Nominal Operating Cell Temperature (NOCT)	45°C

Test Operating Conditions	Value
Maximum Series Fuse	25A
Maximum System Voltage	1500 VDC (UL181E1)
Maximum Load Capacity (Per UL 1703)	5400 PA Snow Load / 5400 PA Wind Load
Fire Performance Class	Class C/Type 1

Packaging Configuration	Value
Number of Modules per Pallet	31
Number of Pallets per 40ft. Container	24
Pallet Dimensions	2030 X 1220 X 1200
Pallet Weight (kg)	76.6
Container Weight (kg)	16,384

Mechanical Properties	Value
Cell Type	Monocrystalline
Glass	3.2mm, tempered, low iron, tempered glass, transmission, low iron, tempered glass
Frame	Anodized Aluminum Alloy
Junction Box	IP68
Dimensions	1903 X 1134 X 35 mm
Output Cable	4mm ² (EU)2AWG-39-37m (1200mm)
Weight	52.9lbs (24kg)
Cable Length	1200mm
Encapsulant	POE



Certifications

UL61730-1, UL61730-2

LEGACY POWER
LEGACY POWER
3333 DIGITAL DR#600, LEHI,
UT 84043, UNITED STATES
PHONE: 855-353-4899

Collette R. Swanson Jr.
ELECTRICAL LIC. U.21498

REVISIONS	DESCRIPTION	DATE	REV
1	REVISION	09/20/2022	A
2	REVISION	11/02/2022	B

Signature with Seal

PROJECT NAME & ADDRESS
RICKY RAYNOR
RESIDENCE
107 PAUL CLAYTON CIR
COATS, NC 27521
PH NO. (919) 625-7661
EMAIL ID: rraynor@harnett.k12.nc.us

DATE: 11/02/2022
SHEET NAME
EQUIPMENT SPECIFICATION

SHEET SIZE
**ANSI B
11" X 17"**

SHEET NUMBER
PV-6



Aptos Solar Technology reserves the right to make specification changes without notice



3140 De La Cruz Blvd., Ste 200
Santa Clara, CA 95054
www.aptosolar.com | info@aptosolar.com



DATA SHEET

IQ8 and IQ8+ Microinverters

Our newest IQ8 Microinverters are the industry's first microgrid-forming, software-defined microinverters with split-phase power conversion capability to convert DC power to AC power efficiently. The brain of the semiconductor-based microinverter is our proprietary application-specific integrated circuit (ASIC) which enables the microinverter to operate in grid-tied or off-grid modes. This chip is built in advanced 55nm technology with high speed digital logic and has super-fast response times to changing loads and grid events, alleviating constraints on battery sizing for home energy systems.



Part of the Enphase Energy System, IQ8 Series Microinverters integrate with the Enphase IQ Battery, Enphase IQ Gateway, and the Enphase App monitoring and analysis software.



IQ8 Series Microinverters redefine reliability standards with more than one million cumulative hours of power-on testing, enabling an industry-leading limited warranty of up to 25 years.



IQ8 Series Microinverters are UL Listed as PV Rapid Shut-Down Equipment and conform with various regulations, when installed according to manufacturer's instructions.



Connect PV modules quickly and easily to IQ8 Series Microinverters using the included O-DCC-2 adapter cable with plug-n-play MCA connectors.

© 2022 Enphase Energy. All rights reserved. Enphase, the Enphase logo, IQ8 Microinverters, and other names are trademarks of Enphase Energy, Inc. Data subject to change.

IQ8SP-DS-0002-01-EN-US-2022-03-17

IQ8 and IQ8+ Microinverters

INPUT DATA (A)	(09-89-2-US)	(09PAUS-72-2-US)
Commonly used module pairings ¹	235 - 350	235 - 440
Module compatibility	60-cell/72D half-cell	60-cell/72D half-cell and 72-cell/144 half-cell
MPP1 voltage range	27 - 37	29 - 45
Operating range	25 - 48	25 - 58
Min/max start voltage	30 / 48	30 / 58
Max input DC voltage	50	60
Max DC current ² (module loc)	A	15
Overvoltage class DC port	II	II
DC port backfeed current	0	0
PV array configuration	1x1 Ungrounded array; No additional DC side protection required; AC side protection requires max 20A per branch circuit	
OUTPUT DATA (A)		
Peak output power	245	300
Max continuous output power	240	290
Nominal (L-L) voltage/range ³	V	240 / 211 - 264
Max continuous output current	A	1.0
Nominal frequency	Hz	60
Extended frequency range	Hz	50 - 68
AC short circuit fault current over 3 cycles	Amps	2
Max units per 20 A (L-L) branch circuit ⁴		13
Total harmonic distortion	%	<5%
Overvoltage class AC port	III	
AC port backfeed current	mA	30
Power factor setting		1.0
Grid-tied power factor (adjustable)	%	0.85 leading - 0.85 lagging
Peak efficiency	%	97.5
CEC weighted efficiency	%	97
Night-time power consumption	mW	60
TEMPERATURE DATA		
Ambient temperature range		-40°C to +60°C (-40°F to +140°F)
Relative humidity range		4% to 100% (condensing)
DC Connector type		MCA
Dimensions (h/WxD)		212 mm (8.3") x 175 mm (6.9") x 30.2 mm (1.2")
Weight		1.08 kg (2.38 lbs)
Cooling		Natural convection - no fans
Approved for wet locations		Yes
Pollution degree		PD3
Enclosure		Class II double-insulated corrosion resistant polymeric enclosure
Environ. category / UV exposure rating		IEEMA Type 6 / outdoor
COMPLIANCE		
Certifications	CA Rule 21 (UL 1741-SA), UL 62109-1, UL 1741/IEEE547, FCC Part 15 Class B, ICES-0033 Class B, CAN/CSA-C22.2 NO. 1071-01	
	This product is UL Listed as PV Rapid Shut-Down Equipment and conforms with NEC 2014, NEC 2017, and NEC 2020 section 690.12 and C221-2018 Rule 64-218 Rapid Shutdown of PV Systems, for AC and DC conductors, when installed according to manufacturer's instructions.	

(1) No enforced DC/AC ratio. See the compatibility calculator at <https://link.enphase.com/module-compatibility>
(2) Maximum continuous input DC current is 10A (3) Nominal voltage range can be extended beyond nominal if required by the utility. (4) Limits may vary; refer to local requirements to define the number of microinverters per branch in your area.

IQ8SP-DS-0002-01-EN-US-2022-03-17

LGCY POWER
LGCY POWER
3333 DIGITAL DR#600, LEHI,
UT 84043, UNITED STATES
PHONE: 855-353-4899
Charles R. Spawson Jr.
ELECTRICAL LIC. U.21498

REVISIONS	DESCRIPTION	DATE	REV
REVISION	09/20/2022	A	
REVISION	11/02/2022	B	

Signature with Seal

PROJECT NAME & ADDRESS
RICKY RAYNOR RESIDENCE
107 PAUL CLAYTON CIR
COATS, NC 27521
PH NO. (919) 625-7661
EMAIL ID: rraynor@harnett.k12.nc.us

DATE: 11/02/2022

SHEET NAME
EQUIPMENT SPECIFICATION

SHEET SIZE
**ANSI B
11" X 17"**

SHEET NUMBER
PV-7

Enphase IQ Combiner 4/4C

X-IQ-AM1-240-4

X-IQ-AM1-240-4C



X-IQ-AM1-240-4C



X-IQ-AM1-240-4

The **Enphase IQ Combiner 4/4C** with Enphase IQ Gateway and integrated LTE-M1 cell modem (included only with IQ Combiner 4C) consolidates interconnection equipment into a single enclosure and streamlines IQ microinverters and storage installations by providing a consistent, pre-wired solution for residential applications. It offers up to four 2-pole input circuits and Eaton BR series busbar assembly.

Smart

- Includes IQ Gateway for communication and control
- Includes Enphase Mobile Connect cellular modem (GELLMODEM-M1-06-SP-05), included only with IQ Combiner 4C
- Includes solar shield to match Enphase IQ Battery aesthetics and deflect heat
- Flexible networking supports Wi-Fi, Ethernet, or cellular
- Optional AC receptacle available for PLC bridge
- Provides production metering and consumption monitoring

Simple

- Centered mounting brackets support single stud mounting
- Supports bottom, back and side conduit entry
- Up to four 2-pole branch circuits for 240 VAC plug-in breakers (not included)
- 80A total PV or storage branch circuits

Reliable

- Durable NRTL-certified NEMA type 3R enclosure
- Five-year limited warranty
- Two years labor reimbursement program coverage included for both the IQ Combiner SKUs
- UL listed

Enphase IQ Combiner 4/4C

MODEL NUMBER

IQ Combiner 4 (X-IQ-AM1-240-4)

IQ Combiner 4C (X-IQ-AM1-240-4C)

ACCESSORIES AND REPLACEMENT PARTS

Enphase Communications Kit
GELLMODEM-M1-06-SP-05
GELLMODEM-M1-06-SP-05
GELLMODEM-M1-06-SP-05
Circuit Breakers
BRK-10A-2-240V
BRK-15A-2-240V
BRK-20A-2-240V
BRK-20A-2-240V-4
BRK-20A-2-240V-8
EPIC-01
XA-SOLARSHIELD-ES
XA-PLUG-10B-3
XA-ENVPICBA-3
X-IR-NK-HB-125A

Includes COMMS-KIT-01 and GELLMODEM-M1-06-SP-05 with 5-year Sprint data plan for LTE-M1 cellular modem with 5-year Sprint data plan
Includes 48 based LTE-M1 cellular modem with 5-year AT&T data plan
Supports Eaton BR210, BR215, BR220, BR230, BR240, BR250, and BR260 circuit breakers.
Circuit breaker, 2 pole, 10A, Eaton BR210
Circuit breaker, 2 pole, 15A, Eaton BR215
Circuit breaker, 2 pole, 20A, Eaton BR220
Power line carrier (communication bridge path), quantity: one pair
Replacement solar shield for IQ Combiner 4/4C
Accessory receptacle for Power Line Carrier in IQ Combiner 4/4C (required for EPIC-01)
Replacement IQ Gateway primed circuit board (PCB) for Combiner 4/4C
Hold down kit for Eaton circuit breaker with screws.

ELECTRICAL SPECIFICATIONS

Rating
System voltage
Eaton IIR series busbar rating
Max. continuous current rating
Max. continuous current rating (input from P/storage)
Max. circuit rating (output)
Branch circuits (input and/or storage)
Max. total branch circuit breaker rating (input)
Physical mounting CT
Consumption monitoring CT (CT-200-SP-LUT)

Continuous duty
120/240 VAC, 60 Hz
125 A
65 A
64 A
99 A
Up to four 2-pole Eaton IIR series Distributed Generation (DG) breakers only (not included)
80A of distributed generation / SSA with IQ Gateway busbar included
200 A solid core pre-installed and wired to IQ Gateway
A pair of 200 A split core current transformers.

MECHANICAL DATA

Dimensions (WxHxD)
Weight
Ambient temperature range
Coating
Enclosure environmental rating
Wire sizes
Altitude
Internet connection options
Integrated Wi-Fi
Cellular
Ethernet
Compliance

37.5 x 48.5 x 16.6 cm (14.75" x 19.09" x 6.53") with mounting brackets.
7.5 kg (16.5 lbs)
-40° C to 140° C (-40° to 115° F)
Neutral connection, pilot heat shield
Outdoor, NRTL-certified, NEMA type 3R, polycarbonate construction
• 20 A to 50 A breaker inputs, 14 to 4 AWG copper conductors
• 80 A breaker branch input, 4 to 1/0 AWG copper conductors
• Main lug combined output: 10 to 2/0 AWG copper conductors
• Main lug combined output: 10 to 2/0 AWG copper conductors
• Always follow local code requirements for conductor sizing.
To 2000 meters (6,560 feet)
802.11b/g/n
GELLMODEM-M1-06-SP-05, GELLMODEM-M1-06-AT-05 (40 based LTE-M1 cellular modem). Note that an Enphase Mobile Connect cellular modem is required for all Enphase installations.
Optional: 800.3, CatBE (or Cat 6) UTP Ethernet cable (not included).
UL 191E, CAN/CSA C22.2 No. 197, 47 CFR, Part 15, Class B, FCC 1500
FCC Part 15, Class B, FCC 1500
Consumption metering accuracy class 2.3
UL 8540-1 (CAN/CSA 22.2 No. 610) 0-1

To learn more about Enphase offerings, visit enphase.com
© 2021 Enphase Energy. All rights reserved. Enphase, the Enphase logo, IQ Combiner 4/4C, and other names are trademarks of Enphase Energy, Inc. Data subject to change: 10/21/2021

ENPHASE
ENPHASE ENERGY
3333 DIGITAL DR#600, LEHI,
UT 84043, UNITED STATES
PHONE: 855-353-4899
Charles R. Swanson Jr.
ELECTRICAL LIC. U.21498

REVISIONS	DESCRIPTION	DATE	REV
REVISION		09/29/2022	A
REVISION		11/02/2022	B

Signature with Seal

PROJECT NAME & ADDRESS
RICKY RAYNOR RESIDENCE
107 PAUL CLAYTON CIR
COATS, NC 27521
PH NO. (919) 625-7661
EMAIL ID: rraynor@harnett.k12.nc.us

DATE: 11/02/2022
SHEET NAME
EQUIPMENT SPECIFICATION

SHEET SIZE
**ANSI B
11" X 17"**

SHEET NUMBER
PV-8



To learn more about Enphase offerings, visit enphase.com



REVISIONS	DESCRIPTION	DATE	REV
REVISION		09/20/2022	A
REVISION		11/02/2022	B

Signature with Seal

PROJECT NAME & ADDRESS
RICKY RAYNOR RESIDENCE
 107 PAUL CLAYTON CIR
 COATS, NC 27521
 PH NO. (919) 625-7661
 EMAIL ID: mraynor@harnett.k12.nc.us

DATE: 11/02/2022

SHEET NAME
EQUIPMENT SPECIFICATION

SHEET SIZE
ANSI B 11" X 17"

SHEET NUMBER
PV-9

Datasheet



Ground Mount System



Mount on all terrains, in no time.

The IronRidge Ground Mount System combines our XR1000 rails with locally-sourced steel pipes, or mechanical tubing, to create a cost-effective structure capable of handling any site or terrain challenge. Installation is simple with only a few structural components and no drilling, welding, or heavy machinery required. In addition, the system works with a variety of foundation options, including concrete piers and driven piles.



Rugged Construction
 Engineered steel and aluminum components ensure durability.



PE Certified
 Pre-stamped engineering letters available in most states.



Simple Assembly
 Just a few simple components and no heavy equipment.



Design Software
 Online tool generates engineering values and bill of materials.



Flexible Architecture
 Multiple foundation and array configuration options.



20 Year Warranty
 Twice the protection offered by competitors.

Datasheet



360° Product Tour
 Visit Ironridge.com

Substructure

Top Caps



Connect vertical and cross pipes.

Bonded Rail Connectors



Attach and bond Rail Assembly to cross pipes.

Diagonal Braces



Optional Brace provides additional support.

Cross Pipe & Piers



Steel pipes or mechanical tubing for substructure.

Rail Assembly

XR100/XR1000 Rails



Curved rails increase spanning capabilities.

UFOs



Universal Fastening Objects bond modules to rails.

Stopper Sleeves



Snap onto the UFO to turn into a bonded end clamp.

CAMO



Bond modules to rails while staying completely hidden.

Resources

Design Assistant



Go from rough layout to fully engineered system. For free. Go to Ironridge.com/design

NABCEP Certified Training





Earn free continuing education credits while learning more about our systems. Go to Ironridge.com/training

Project Details	
Name	Ricky Raynor
Date	11/02/2022
Location	107 Paul Clayton Circle, Coats, NC 27521
Total modules	19
Module	Custom Panels: APTOS-DMA-120-MF10-440W
Dimensions	Dimensions: 74.92" x 44.65" x 1.38" (1903.0mm x 1134.0mm x 35.0mm)
Total watts	8,360 kW
ASCE code	7.16
Wind speed	110 mph
Snow load	20 psf
Wind exposure	C
Piers	12
Concrete	2.48 yd ³

Substructure & Foundation	
Tilt	20°
South facing grade	0°
Pipe/tubing diameter	2"
Soil class	Concrete
Foundation type	Concrete
Hole diameter	16"

Sub array #1	
Rows	4
Area	31' 4" (EW) x 15' 2" (NS)
E/W spacing	6'
Piers/array	12
Total cross pipes	2 (31' 4")
Shear	635 lbs
Columns	5
Rail type	XRL000
Rail cantilever	3' 9"
Total south piers	6 (5' 1")
Total pipe length	143' 2"
Moment	0 ft-lbs
Uplift	-1,227 lbs
# Arrays	1
Diagonal bracing	yes
Pipe cantilever	8"
Total north piers	6 (8' 4")
Cut back modules	1



DESCRIPTION	DATE	REV
REVISIONS		
REVISION	09/20/2022	A
REVISION	11/02/2022	B

Signature with Seal

RICKY RAYNOR
RESIDENCE
107 PAUL CLAYTON CIR
COATS, NC 27521
PH NO. (919) 625-7661
EMAIL ID: rraynor@harnett.k12.nc.us

DATE: 11/02/2022

SHEET NAME
EQUIPMENT
SPECIFICATION

SHEET SIZE
ANSI B
11" X 17"

SHEET NUMBER
PV-10

DESCRIPTION	DATE	REV
REVISION	09/20/2022	A
REVISION	11/02/2022	B

Signature with Seal


PROJECT NAME & ADDRESS
**RICKY RAYNOR
RESIDENCE
107 PAUL CLAYTON CIR
COATS, NC 27521
PH NO. (919) 625-7661
EMAIL ID: rraynor@harnett.k12.nc.us**

DATE: 11/02/2022

SHEET NAME
**EQUIPMENT
SPECIFICATION**


SHEET SIZE
**ANSI B
11" X 17"**

SHEET NUMBER
PV-11




Pipe Fitting Detail


XRL1000 Rail



Clamp Detail



Grounding Diagram



Bill of Materials

Part	Spares	Total Qty
Rails		
XR-1000-204A XR1000, Rail 204" (17 Feet) Clear	0	10
Clamps & Grounding		
UFO-CL-03-A1 Universal Module Clamp, Clear	0	48
UFO-STP-35MM-M1 Stopper Sleeve, 35MM, Mill	0	20
XR-LLG-03A.1 Grounding Lug, Low Profile	0	1
Substructure		
70-0200-SCA SGA 700 Cbr 4" 2"	0	12
GM-BIC-002 Ground Mount Bonded Rail Connector - 2"	0	20
70-0205-CBR SGA 2" Bracer Assembly (S-Panel) (bulk)	0	6

Signature with Seal

PROJECT NAME & ADDRESS

RICKY RAYNOR
RESIDENCE
107 PAUL CLAYTON CIR
COATS, NC 27521
PH NO. (919) 625-7661
EMAIL ID: rraynor@harnett.k12.nc.us

DATE: 11/02/2022

SHEET NAME
EQUIPMENT SPECIFICATION

SHEET SIZE
**ANSI B
11" X 17"**

SHEET NUMBER
PV-12



ELECTRICAL GROUNDING W/ SPlice & THERMAL BREAK

ENPHASE MICROINVERTER FOR INSTALLATION GUIDE

LG CY POWER
 LG CY POWER
 3333 DIGITAL DR#600, LEHI,
 UT 84043, UNITED STATES
 PHONE: 855-353-4899
Collette R. Spawson 7c
 ELECTRICAL LIC. U.21498


REVISIONS	DESCRIPTION	DATE	REV
REVISION		09/20/2022	A
REVISION		11/02/2022	B

Signature with Seal


PROJECT NAME & ADDRESS
 RICKY RAYNOR
 RESIDENCE
 107 PAUL CLAYTON CIR
 COATS, NC 27521
 PH NO. (919) 625-7661
 EMAIL ID: rraynor@harnett.k12.nc.us

DATE: 11/02/2022
 SHEET NAME
 EQUIPMENT
 SPECIFICATION
 SHEET SIZE
 ANSI B
 11" X 17"
 SHEET NUMBER
 PV-13




EXPANSION JOINT W/ ELECTRICAL BONDING CONNECTION
 Enphase Microinverter (MI) Requirements
 (Model No. M215 & M250)
 Min. 3 Microinverters on each side of thermal break



EXPANSION JOINT W/ GROUNDING LUGS & COPPER JUMPER
 Enphase Microinverter (MI) Requirements
 (Model No. M215 & M250)
 3 or more Microinverters sharing same trunk cable & rails



CONTINUOUS RAIL & ELECTRICAL BONDING SPICE
 Enphase Microinverter (MI) Requirements
 (Model No. M215 & M250)
 3 Microinverters sharing same trunk cable & rails



ELECTRICAL BONDING SPICE

EXPANSION JOINT USED AS THERMAL BREAK W/
GROUNDING LUGS & COPPER JUMPER

EXPANSION JOINT USED AS THERMAL BREAK W/O
ELECTRICAL BONDING CONNECTION

NOTE: THE ABOVE IMAGES ARE SAMPLE CONFIGURATIONS TO ILLUSTRATE THE REQUIREMENTS FOR A SYSTEM GROUNDING THROUGH ENPHASE MICROINVERTERS DESCRIBED ON PAGE 1

DESCRIPTION	DATE	REV
REVISION	09/20/2022	A
REVISION	11/02/2022	B

Signature with Seal

PROJECT NAME & ADDRESS

RICKY RAYNOR
 RESIDENCE
 107 PAUL CLAYTON CIR
 COATS, NC 27521
 PH NO. (919) 625-7661
 EMAIL ID: mraynor@harnett.k12.nc.us

DATE: 11/02/2022

SHEET NAME
**EQUIPMENT
 SPECIFICATION**

SHEET SIZE
**ANSI B
 11" X 17"**

SHEET NUMBER
PV-14



Components and Cladding Roof Zones:
 The Components and Cladding Roof Zones shall be determined based on ASCE 7-05 and ASCE 7-10 Component and Cladding design.

- Notes:**
- 1) U-builder Online tool analysis is only for Unirac SM SOLARMOUNT Rail Flush systems only and do not include roof capacity check.
 - 2) Risk Category II per ASCE 7-10.
 - 3) Topographic factor, kzt is 1.0.
 - 4) Average parapet height is 0.0 ft.
 - 5) Wind speeds are LRFD values.
 - 6) Attachment spacing(s) apply to a seismic design category E or less.


Design Responsibility:
 The U-Builder design software is intended to be used under the responsible charge of a registered design professional where required by the authority having jurisdiction. In all cases, this U-builder software should be used under the direction of a design professional with sufficient structural engineering knowledge and experience to be able to:

- Evaluate whether the U-Builder Software is applicable to the project, and
- Understand and determine the appropriate values for all input parameters of the U-Builder software.

This letter certifies that the Unirac SM SOLARMOUNT Rails Flush, when installed according to the U-Builder engineering report and the manufacture specifications, is in compliance with the above codes and loading criteria.

- This certification excludes evaluation of the following components:
- 1) The structure to support the loads imposed on the building by the array, including, but not limited to: strength and deflection of structural framing members, fastening and/or strength of roofing materials, and/or the effects of snow accumulation on the structure.
 - 2) The attachment of the SM SOLARMOUNT Rails to the existing structure.
 - 3) The capacity of the solar module frame to resist the loads.

This requires additional knowledge of the building and is outside the scope of the certification of this racking system. If you have any questions on the above, do not hesitate to call.



DIGITALLY SIGNED
 03/28/2022

Prepared by:
 PZSE, Inc. – Structural Engineers
 Roseville, CA

1478 Stone Point Drive, Suite 190, Roseville, CA 95661
 T 916.961.3960 F 916.961.3965 W www.pzse.com
 Experience | Integrity | Empowerment



March 28, 2022
 Unirac
 1411 Broadway Blvd. NE
 Albuquerque, NM 87102

Attn.: Unirac - Engineering Department

Re: Engineering Certification for the Unirac U-Builder 2.0 SOLARMOUNT Flush Rail

PZSE, Inc. - Structural Engineers has reviewed the Unirac SOLARMOUNT rails, proprietary mounting system constructed from modular parts which is intended for rooftop installation of solar photovoltaic (PV) panels; and has reviewed the U-builder Online tool. This U-Builder software includes analysis for the SOLARMOUNT LIGHT rail, SOLARMOUNT STANDARD rail, and SOLARMOUNT HEAVY DUTY rail with Standard and Pro Series hardware. All information, data and analysis contained within are based on, and comply with the following codes and typical specifications:

1. Minimum Design Loads for Buildings and other Structures, ASCE/SEI 7-05 and ASCE/SEI 7-10
2. 2006-2015 International Building Code, by International Code Council, Inc.
3. 2006-2015 International Residential Code, by International Code Council, Inc.
4. AC428, Acceptance Criteria for Modular Framing Systems Used to Support Photovoltaic (PV) Panels, November 1, 2012 by ICC-ES.
5. 2015 Aluminum Design Manual, by The Aluminum Association, 2015

Following are typical specifications to meet the above code requirements:

- Design Criteria:**
- Ground Snow Load = 0 - 100 (psf)
 - Basic Wind Speed = 85 - 190 (mph)
 - Roof Mean Height = 0 - 60 (ft)
 - Roof Pitch = 0 - 45 (Degrees)
 - Exposure Category = B, C & D
 - Per U-builder Engineering report.

Attachment Spacing: Maximum cantilever length is L/3, where "L" is the span noted in the U-Builder online tool.

Cantilever: 2" to 10" clear from top of roof to top of PV panel.

Clearance: 1.0" tolerance for any specified dimension in this report is allowed for installation.

Tolerance(s): See SOLARMOUNT Rail Flush Installation Guide.
Installation Orientation: Landscape - PV Panel long dimension is parallel to ridge/eave line of roof and the PV panel is mounted on the long side.
 Portrait - PV Panel short dimension is parallel to ridge/eave line of roof and the PV panel is mounted on the short side.

1478 Stone Point Drive, Suite 190, Roseville, CA 95661
 T 916.961.3960 F 916.961.3965 W www.pzse.com
 Experience | Integrity | Empowerment