



# Permit Inspections Harnett County

**Permit Number: EMRES2306-0002**

Description: **Only system- heat pump package changeout**

Applied: **6/1/2023**

Approved: **6/12/2023**

Site Address: **403 W I ST**

Issued: **6/12/2023**

Finalized: **6/22/2023**

City, State Zip Code: **ERWIN, NC 28339**

Status: **FINALED**

Applicant: **6&Fix Heating & Cooling**

Parent Permit:

Owner: **BOGLE JOSHUA J**

Parent Project:

Contractor: **6&Fix Heating & Cooling**

Details:

## LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
	6/14/2023	6/14/2023	FINAL**	Deen Taylor	DISAPPROVED	eTRAKiT Inspection Request

Notes:

6/13/2023 11:11 AM 6&Fix Heating & Cooling  
 Can we please have an AM inspection? Homeowner will be on site to give access. JJ 919-901-7189.  
 Ashlei will be contact in the office, with 6 & Fix if needed. 919-736-6661 x1108  
 Contact Name: 6&Fix Heating & Cooling  
 Site Address: 403 W I ST  
 Phone: 9197366661  
 e-Mail: install@6andfix.com

Ductwork in package unit install the different times, both without permits. Contractors who installed new equipment are not on current permit. Licensed HVAC contractor must ensure all new components are code compliant, unit label is marked and call for reinspection

	6/22/2023	6/22/2023	FINAL**	Deen Taylor	APPROVED	eTRAKiT Inspection Request
--	-----------	-----------	---------	-------------	----------	----------------------------

Notes:

6/20/2023 11:53 AM 6&Fix Heating & Cooling  
 Can we please have the earliest time, or last time of the day? Sandy will meet the inspector. 984-800-2995  
 Contact Name: 6&Fix Heating & Cooling  
 Site Address: 403 W I ST  
 Phone: 9199088763  
 e-Mail: install@6andfix.com

