



Permit Inspections

Harnett County

Permit Number: **EMRES2508-0011**

Description: replaced 2 ton heat pump air handler in crawl 1st floor

Applied: **8/5/2025**

Approved: **8/5/2025**

Site Address: **233 STONEY CREEK DR**

Issued: **9/16/2025**

Finalized:

City, State Zip Code: **SANFORD, NC 27332**

Status: **ISSUED**

Applicant: **MICHAEL AND SONS SERVICES**

Parent Permit:

Owner: **LABELLE CLAIRE**

Parent Project:

Contractor: **MICHAEL AND SONS SERVICES**

Details:

LIST OF INSPECTIONS

| SEQ ID | SCHEDULED DATE | COMPLETED DATE | TYPE | INSPECTOR | RESULT | REMARKS |
|---|----------------|----------------|---------|-------------------|-------------|---------|
| | | | FINAL** | James T Hall | | |
| Notes: | | | | | | |
| | 9/18/2025 | 9/18/2025 | FINAL** | Ricardo D Honrada | DISAPPROVED | |
| Notes: Ref residential building code M1305.1.4.1.3 support of AHU.Need support the supply and return plenum. | | | | | | |