

Attempt to Repair

06-20060153

HARNETT COUNTY HEALTH DEPARTMENT

No 17719

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) MARCEUS WHITT

New Installation Septic Tank

Property Location: SR# 152 Brookstone Pt.

Repairs Nitrification Line

Subdivision Brookstone

Lot # 55

Tax ID # _____

Quadrant # _____

Number of Bedrooms Proposed: 3 existing

Lot Size: 2.0+ Acres

Basement with Plumbing:

Garage:

Water Supply: Well Public

Community

Distance From Well: 55 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: _____ gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches _____ exact length of each ditch _____ ft. width of ditches _____ ft. depth of ditches _____ in.

French Drain Required: _____ Linear feet

Date: 3-27-00

This permit is subject to revocation if site plans or intended use change.

Signed: [Signature]
Environmental Health Specialist

keep "D" Box Adjusted -

Place Gutters on house to divert surface water

Divert All surface water away from septic area.

Area The cover & soil has been washed from the

septic system needs to be replaced.

check for leaks.